



## **ADDENDUM 1**

**Date: December 5, 2025**

**Pages: One Page**

**PROJECT NUMBER: 11-25-001**

**PROJECT: UPS Replacement at Aurora Downtown Campus**

**This addendum does not change the bid due date or time.**

Respondent must acknowledge receipt of this addendum with their submittal.

### **QUESTIONS**

1. In the scope of work, scope #7, will the contractor be required to pull the wire back and install new? Or can the existing alarm wiring, temperature sensor wiring, and status wiring be reused?
  - a. Can be re-used if not damaged
2. Can the transport of the UPS's be performed during normal working hours?
  - a. It will require coordination with the college for during a time when there are no classes or on a Friday when there are fewer people on campus.