



ADDENDUM 1

Date: Thursday, August 27, 2026 – 12:00 p.m.

Pages: 0092 Pages

PROJECT NUMBER: #08-26-001

PROJECT: Life Safety Services

DUE: Thursday, August 27, 2026

This addendum does not change the bid due date or time.

Respondent must acknowledge receipt of this addendum with their submittal.

QUESTIONS

I attached the scope of work and test reports. This should answer how many devices each that we have +or- %10.

Scope Clarification

Can the college provide an inventory of all fire protection equipment by campus?

- Fire extinguishers
- Emergency Lighting
- Wet Pipe Sprinkler Systems
- Dry Pipe Sprinkler Systems
- Fire Pump Types (also GPM)
- Fire Hydrants
- Clean Agent Suppression Systems and Types (FM-200, Novec 1230, Inergen, Other)

What type of fire extinguisher training is the college looking to receive and how many employees will need to attend per campus?

- Live Fire
- Classroom Only
- Combination Classroom and Live Fire

This would be a minimal training event for Ops staff; this event would be once a year at the ops building. Less than twenty

Can the college provide the most recent inspection reports for all life safety systems? See attached

Can the college clarify if these Testing & Certifications are associated with Fire Protection Services?

- 5.17.8 Battery Backup Inverter Testing-This would be at Erickson only
- 5.17.9 Exercise associated hydronic valves-This is not a part of the Fire protection

REQUEST FOR PROPOSAL
#08-26-001 Life Safety Services
Thursday, August 27, 2026 @Noon

5.17.10 Grease/oil associated pumps/motors with hydronic system-**This is not a part of the Fire protection**

5.17.12 Remove and replace any panels associated with inspection of boilers-**This is not a part of the Fire protection**

Service & Response Questions

Does the required 2-hour response time apply to both critical and non-critical emergencies?-**Critical**

Is remote troubleshooting acceptable to satisfy the initial response requirement?-**Not for critical but ok for non-critical**

Pricing Questions

Should annual inspection/testing pricing be included in hourly labor rates, or submitted separately as fixed-price services?-**This should be separate**

Are the hourly labor rates being provided as the primary pricing methodology for all services-**only for repair quotes**, and is submitting separate system-based or unit-based pricing acceptable?

Will prevailing wage requirements apply only to corrective repairs or to inspections as well?-**YES**

Are all deficiencies and corrective actions expected to be quoted separately or, if applicable, can deficiencies be corrected during the time of inspections?- **Quoted separately.**

CHANGES

CLARIFICATIONS

Sugar Grove

Rt. 47 at Waubensee Drive
Sugar Grove, IL 60554-9454
(630) 466-7900

Aurora Downtown

18 S. River St.
Aurora, IL 60506-4131
(630) 801-7900

Aurora Fox Valley

2060 Ogden Ave.
Aurora, IL 60504-7222
(630) 585-7900

Plano

100 Waubensee Drive
Plano, IL 60545-2276
(630) 552-7900

Report to:
Property: WCC, Aurora, 18 S River St
Address: 18 South River Street
City: Aurora
State: IL **Zip:** 60506

Date: 10/23/2021
Job Number:
Technician: T

Annual FIRE SPRINKLER INSPECTION REPORT

Central Station	POS/Acct	Handled by customer	Out	IN
-----------------	----------	---------------------	-----	----

GENERAL	YES	NO	N/A	Note #
Is the building currently occupied?	☒	☐	☐	
Has the occupancy classification and hazard of contents remained the same since the last inspection?	☒	☐	☐	
Are all fire protection systems in service?	☒	☐	☐	
Has the system remained in service without modifications or actuations of devices/alarms since last inspection?	☒	☐	☐	
Fire pump onsite?	☐	☒	☐	

SPRINKLERS (visible)	YES	NO	N/A	Note #
Free of damage or leaks?	☒	☐	☐	
Free of corrosion, foreign material, or paint, loading?	☒	☐	☐	
Installed in proper orientation?	☒	☐	☐	
Fluid in glass bulbs?	☒	☐	☐	
Spare head box contains proper number and type of heads, including wrench(s)?	☒	☐	☐	
Escutcheon plates are present and installed correctly?	☒	☐	☐	
Minimum clearance between sprinklers and storage?	☒	☐	☐	
Sprinklers tested or replaced per appropriate testing schedule?	☒	☐	☐	

Sprinkler heads in use and earliest date on heads:

Standard: _____ Quick Response: ☒ 2009 ESFR: _____ Dry Pendant: _____

PIPING	YES	NO	N/A	Note #
In good condition with no external corrosion?	☒	☐	☐	
No leaks or mechanical damage?	☒	☐	☐	
Correct alignment/No external loads?	☒	☐	☐	
Wet Sprinkler piping not exposed to freezing temperatures?	☒	☐	☐	
Hangers/bracing not damaged or loose?	☒	☐	☐	

FIRE DEPARTMENT CONNECTIONS	YES	NO	N/A	Note #
Visible and accessible?	☒	☐	☐	
Couplings swivel and operate properly?	☒	☐	☐	
Plugs or caps in place?	☒	☐	☐	
Identification signs are in place?	☒	☐	☐	
Ball drip valve is functional/not leaking?	☒	☐	☐	

ANTI-FREEZE SYSTEMS	YES	NO	N/A	Note #
Have all anti-freeze systems been tested?	☐	☐	☒	
Proper signage and placard info in place?	☐	☐	☒	

LOCATION / AREA PROTECTED	TEMP	Note #	LOCATION / AREA PROTECTED	TEMP	Note #
1			3		
2			4		

(*Any additional anti-freeze system results will be listed in Note # Section)

Report to:
Property: WCC, Aurora, 18 S River St
Address: 18 South River Street
City: Aurora
State: IL **Zip:** 60506

Date: 10/23/2021
Job Number:
Technician:

Annual FIRE SPRINKLER INSPECTION REPORT

5-water gauges, 1 compound gauge)

<i>FIVE YEAR REQUIREMENTS</i>	YES	NO	N/A	Note #
Have all Check Valves, Pre-action or Deluge Valves been internally inspected within the last 5 years?	☐	☒	☐	1
Has the piping in all systems been checked for obstructive materials within the last 5 years?	☐	☒	☐	1
System Gauges tested or replaced within the last 5 years?	☐	☒	☐	2

<i>CONTROL VALVES</i>	YES	NO	N/A	Note #
All Control Valves in the correct (open or closed) position?	☒	☐	☐	
Locked or supervised?	☒	☐	☐	
Easily accessible?	☒	☐	☐	
Free from damage or leaks?	☒	☐	☐	
Proper signage in place?	☒	☐	☐	
Tamper Switches operate properly?	☒	☐	☐	
All Control Valves operated through full range and return to normal position?	☒	☐	☐	
OS&Y Valves properly lubricated?	☒	☐	☐	

Description	Type	Size	Location	Note #
City 1	OS&Y	8	Sprinkler room	
City 2	OS&Y	8	Sprinkler room	
Fire pump suction	OS&Y	8	Sprinkler room	
Fire pump discharge	OS&Y	8	Sprinkler room	
Main riser	Butterfly	6"	Sprinkler room	
Bypass 1	Butterfly	6"	Sprinkler room	
Bypass 2	Butterfly	6"	Sprinkler room	
4th Floor	Butterfly	2"	4th Floor Center Stairwell	
2nd Floor	Butterfly	2 1/2"	2nd Floor Center Stairwell	
Fire pump test header	OS&Y	6"	Sprinkler room	

(*Any additional control valves will be listed on a separate sheet.)

<i>MAIN DRAIN AND WATERFLOW TEST RESULTS</i>	YES	NO	N/A	Note #
Do main drain test results differ more than 10% from previous test?	☐	☒	☐	

System #	Riser Size	Size of Test Pipe	PSI Static Pressure Before	PSI Residual Pressure	PSI Pressure After	Waterflow Time (sec)	Note #
First floor riser	4"	2"	70	65	70	W/60	
Main riser feed	6"	2"	70	65	70	W/60	
4th Floor	2"	1 1/4"	70	65	70	W/60	
3rd Floor	2"	1 1/4"	70	65	70	W/60	
2nd Floor	2 1/2"	1 1/4"	70	65	70	W/60	

(*Any additional main drain/waterflow results will be listed on a separate sheet.)

Report to:**Property:** WCC, Fox Valley, 2060 Ogden Ave**Address:** 2060 Ogden Avenue**City:** Aurora**State:** IL **Zip:** 60504**Date:****Job Number:****Technician:**

Annual FIRE SPRINKLER INSPECTION REPORT

Central Station	POS/Acct	Handled by customer	Out	IN
-----------------	----------	---------------------	-----	----

GENERAL	YES	NO	N/A	Note #
Is the building currently occupied?	☒	☐	☐	
Has the occupancy classification and hazard of contents remained the same since the last inspection?	☒	☐	☐	
Are all fire protection systems in service?	☒	☐	☐	
Has the system remained in service without modifications or actuations of devices/alarms since last inspection?	☒	☐	☐	
Fire pump onsite?	☐	☒	☐	

SPRINKLERS (visible)	YES	NO	N/A	Note #
Free of damage or leaks?	☒	☐	☐	
Free of corrosion, foreign material, or paint, loading?	☒	☐	☐	
Installed in proper orientation?	☒	☐	☐	
Fluid in glass bulbs?	☒	☐	☐	
Spare head box contains proper number and type of heads, including wrench(s)?	☒	☐	☐	
Escutcheon plates are present and installed correctly?	☒	☐	☐	
Minimum clearance between sprinklers and storage?	☒	☐	☐	
Sprinklers tested or replaced per appropriate testing schedule?	☒	☐	☐	

Sprinkler heads in use and earliest date on heads:

Standard: ☒ 2009 Quick Response: _____ ESFR: _____ Dry Pendant: _____

PIPING	YES	NO	N/A	Note #
In good condition with no external corrosion?	☒	☐	☐	
No leaks or mechanical damage?	☒	☐	☐	
Correct alignment/No external loads?	☒	☐	☐	
Wet Sprinkler piping not exposed to freezing temperatures?	☒	☐	☐	
Hangers/bracing not damaged or loose?	☒	☐	☐	

FIRE DEPARTMENT CONNECTIONS	YES	NO	N/A	Note #
Visible and accessible?	☒	☐	☐	
Couplings swivel and operate properly?	☒	☐	☐	
Plugs or caps in place?	☒	☐	☐	
Identification signs are in place?	☒	☐	☐	
Ball drip valve is functional/not leaking?	☒	☐	☐	

ANTI-FREEZE SYSTEMS	YES	NO	N/A	Note #
Have all anti-freeze systems been tested?	☐	☐	☒	
Proper signage and placard info in place?	☐	☐	☒	

LOCATION / AREA PROTECTED	TEMP	Note #	LOCATION / AREA PROTECTED	TEMP	Note #
1			3		
2			4		

(*Any additional anti-freeze system results will be listed in Note # Section)

Report to:**Property:** WCC, Fox Valley, 2060 Ogden Ave**Address:** 2060 Ogden Avenue**City:** Aurora**State:** IL **Zip:** 60504**Date:****Job Number:****Technician:****Annual FIRE SPRINKLER INSPECTION REPORT**

FIVE YEAR REQUIREMENTS	YES	NO	N/A	Note #
Have all Check Valves, Pre-action or Deluge Valves been internally inspected within the last 5 years?	☐	☒	☐	
Has the piping in all systems been checked for obstructive materials within the last 5 years?	☐	☒	☐	
System Gauges tested or replaced within the last 5 years?	☒	☐	☐	2019

CONTROL VALVES	YES	NO	N/A	Note #
All Control Valves in the correct (open or closed) position?	☒	☐	☐	
Locked or supervised?	☒	☐	☐	
Easily accessible?	☒	☐	☐	
Free from damage or leaks?	☒	☐	☐	
Proper signage in place?	☒	☐	☐	
Tamper Switches operate properly?	☒	☐	☐	
All Control Valves operated through full range and return to normal position?	☒	☐	☐	
OS&Y Valves properly lubricated?	☒	☐	☐	

Description	Type	Size	Location	Note #
City 1	OS&Y	8"	Sprinkler room	
City 2	OS&Y	8"	Sprinkler room	
Basement	Butterfly	2"	Sprinkler room	
1st floor	Butterfly	3"	Staff workroom off stair 2	
2nd floor	Butterfly	3"	2nd floor stairs	

(*Any additional control valves will be listed on a separate sheet.)

MAIN DRAIN AND WATERFLOW TEST RESULTS	YES	NO	N/A	Note #
Do main drain test results differ more than 10% from previous test?	☐	☒	☐	

System #	Riser Size	Size of Test Pipe	PSI Static Pressure Before	PSI Residual Pressure	PSI Pressure After	Waterflow Time (sec)	Note #
Main riser	4"	2"	65	45	55	W/60	
1st floor	3"	>	65	45	55	W/60	
2nd floor	3"	1"	65	45	55	W/60	
Basement	2"	1"	65	45	55	W/60	

(*Any additional main drain/waterflow results will be listed on a separate sheet.)



2760 Beverly Dr.
Suite 9
Aurora, IL 60502
630.506.5535
www.allegiantfire.net

Report to: U.S. Fire & Safety Equipment Company
Property: WCC, Auditorium, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL **Zip:** 60554

Date: 10/13/2021
Job Number: 23057286
Technician: Michael Messacar, Jason Brut

Annual FIRE SPRINKLER INSPECTION REPORT

Central Station	Customer takes	POS/Acct	Out	Out	Of	IN	Service
-----------------	----------------	----------	-----	-----	----	----	---------

GENERAL	YES	NO	N/A	Note #
Is the building currently occupied?	☒	☐	☐	
Has the occupancy classification and hazard of contents remained the same since the last inspection?	☒	☐	☐	
Are all fire protection systems in service?	☒	☐	☐	
Has the system remained in service without modifications or actuations of devices/alarms since last inspection?	☒	☐	☐	
Fire pump onsite?	☐	☒	☐	

SPRINKLERS (visible)	YES	NO	N/A	Note #
Free of damage or leaks?	☒	☐	☐	
Free of corrosion, foreign material, or paint, loading?	☒	☐	☐	
Installed in proper orientation?	☒	☐	☐	
Fluid in glass bulbs?	☒	☐	☐	
Spare head box contains proper number and type of heads, including wrench(s)?	☒	☐	☐	
Escutcheon plates are present and installed correctly?	☒	☐	☐	
Minimum clearance between sprinklers and storage?	☒	☐	☐	
Sprinklers tested or replaced per appropriate testing schedule?	☒	☐	☐	

Sprinkler heads in use and earliest date on heads:

Standard: ☒ 2004 Quick Response: _____ ESFR: _____ Dry Pendant: _____

PIPING	YES	NO	N/A	Note #
In good condition with no external corrosion?	☒	☐	☐	
No leaks or mechanical damage?	☒	☐	☐	
Correct alignment/No external loads?	☒	☐	☐	
Wet Sprinkler piping not exposed to freezing temperatures?	☒	☐	☐	
Hangers/bracing not damaged or loose?	☒	☐	☐	

FIRE DEPARTMENT CONNECTIONS	YES	NO	N/A	Note #
Visible and accessible?	☒	☐	☐	
Couplings swivel and operate properly?	☒	☐	☐	
Plugs or caps in place?	☒	☐	☐	
Identification signs are in place?	☒	☐	☐	
Ball drip valve is functional/not leaking?	☒	☐	☐	

ANTI-FREEZE SYSTEMS	YES	NO	N/A	Note #
Have all anti-freeze systems been tested?	☐	☐	☒	
Proper signage and placard info in place?	☐	☐	☒	

LOCATION / AREA PROTECTED	TEMP	Note #	LOCATION / AREA PROTECTED	TEMP	Note #
1			3		
2			4		

(*Any additional anti-freeze system results will be listed in Note # Section)



2760 Beverly Dr.
Suite 9
Aurora, IL 60502
630.506.5535
www.allegiantfire.net

Report to: U.S. Fire & Safety Equipment Company
Property: WCC, Auditorium, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL **Zip:** 60554

Date: 10/13/2021
Job Number: 23057286
Technician: Michael Messacar, Jason Brut

Annual FIRE SPRINKLER INSPECTION REPORT

<i>FIVE YEAR REQUIREMENTS</i>	YES	NO	N/A	Note #
Have all Check Valves, Pre-action or Deluge Valves been internally inspected within the last 5 years?	☒	☐	☐	2018
Has the piping in all systems been checked for obstructive materials within the last 5 years?	☒	☐	☐	2018
System Gauges tested or replaced within the last 5 years?	☒	☐	☐	2018

<i>CONTROL VALVES</i>	YES	NO	N/A	Note #
All Control Valves in the correct (open or closed) position?	☒	☐	☐	
Locked or supervised?	☒	☐	☐	
Easily accessible?	☒	☐	☐	
Free from damage or leaks?	☒	☐	☐	
Proper signage in place?	☒	☐	☐	
Tamper Switches operate properly?	☒	☐	☐	
All Control Valves operated through full range and return to normal position?	☒	☐	☐	
OS&Y Valves properly lubricated?	☒	☐	☐	

<i>Description</i>	<i>Type</i>	<i>Size</i>	<i>Location</i>	<i>Note #</i>
Before Backflow	OS&Y	3"	Sprinkler Room	
After Backflow	OS&Y	3"	Sprinkler Room	

(*Any additional control valves will be listed on a separate sheet.)

<i>MAIN DRAIN AND WATERFLOW TEST RESULTS</i>	YES	NO	N/A	Note #
Do main drain test results differ more than 10% from previous test?	☐	☒	☐	

<i>System #</i>	<i>Riser Size</i>	<i>Size of Test Pipe</i>	<i>PSI Static Pressure Before</i>	<i>PSI Residual Pressure</i>	<i>PSI Pressure After</i>	<i>Waterflow Time (sec)</i>	<i>Note #</i>
Riser 1	3"	2"	75	55	65	W/60	

(*Any additional main drain/waterflow results will be listed on a separate sheet.)



2760 Beverly Dr.
Suite 9
Aurora, IL 60502
630.506.5535
www.allegiantfire.net

Report to: U.S. Fire & Safety Equipment Company
Property: WCC, Auditorium, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL **Zip:** 60554

Date: 10/13/2021
Job Number: 23057286
Technician: Michael Messacar, Jason Brut

Annual FIRE SPRINKLER INSPECTION REPORT

*THE INSPECTOR SUGGESTS THE FOLLOWING NECESSARY IMPROVEMENTS:
(these suggestions are not the result of an engineering survey)*

Note #

MODIFICATIONS OR CORRECTIONS MADE DURING THIS INSPECTION:

INSPECTION & SUGGESTED IMPROVEMENTS WERE DISCUSSED WITH THE UNDERSIGNED OWNER OR OWNERS REPRESENTATIVE:

By this signature, I certify: I state that the information on this form is correct at the time and place of my inspection, and that all equipment tested now was left in operational condition upon completion of this inspection except as noted in comments above.

Verbal checkout with Laura

OWNER / REPRESENTATIVE SIGNATURE

Verbal checkout with Laura

PRINT NAME

10/13/2021

DATE

INSPECTOR SIGNATURE

Michael Messacar, Jason Brut

PRINT NAME

149731

NICET #



2760 Beverly Dr.
Suite 9
Aurora, IL 60502
630.506.5535
www.allegiantfire.net

Report to: U.S. Fire & Safety Equipment Company
Property: WCC, Building A, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL **Zip:** 60554

Date: 10/13/2021
Job Number: 23057292
Technician: Michael Messacar, Jason Brut

Annual FIRE SPRINKLER INSPECTION REPORT

Central Station	Customer takes	POS/Acct	Out	Out	Of	IN	Service
-----------------	----------------	----------	-----	-----	----	----	---------

GENERAL	YES	NO	N/A	Note #
Is the building currently occupied?	☒	☐	☐	
Has the occupancy classification and hazard of contents remained the same since the last inspection?	☒	☐	☐	
Are all fire protection systems in service?	☒	☐	☐	
Has the system remained in service without modifications or actuations of devices/alarms since last inspection?	☒	☐	☐	
Fire pump onsite?	☐	☒	☐	

SPRINKLERS (visible)	YES	NO	N/A	Note #
Free of damage or leaks?	☒	☐	☐	
Free of corrosion, foreign material, or paint, loading?	☒	☐	☐	
Installed in proper orientation?	☒	☐	☐	
Fluid in glass bulbs?	☒	☐	☐	
Spare head box contains proper number and type of heads, including wrench(s)?	☒	☐	☐	
Escutcheon plates are present and installed correctly?	☒	☐	☐	
Minimum clearance between sprinklers and storage?	☒	☐	☐	
Sprinklers tested or replaced per appropriate testing schedule?	☒	☐	☐	

Sprinkler heads in use and earliest date on heads:

Standard: ☒ 2000 Quick Response: _____ ESFR: _____ Dry Pendant: _____

PIPING	YES	NO	N/A	Note #
In good condition with no external corrosion?	☒	☐	☐	
No leaks or mechanical damage?	☒	☐	☐	
Correct alignment/No external loads?	☒	☐	☐	
Wet Sprinkler piping not exposed to freezing temperatures?	☒	☐	☐	
Hangers/bracing not damaged or loose?	☒	☐	☐	

FIRE DEPARTMENT CONNECTIONS	YES	NO	N/A	Note #
Visible and accessible?	☒	☐	☐	
Couplings swivel and operate properly?	☒	☐	☐	
Plugs or caps in place?	☒	☐	☐	
Identification signs are in place?	☒	☐	☐	
Ball drip valve is functional/not leaking?	☒	☐	☐	

ANTI-FREEZE SYSTEMS	YES	NO	N/A	Note #
Have all anti-freeze systems been tested?	☐	☐	☒	
Proper signage and placard info in place?	☐	☐	☒	

LOCATION / AREA PROTECTED	TEMP	Note #	LOCATION / AREA PROTECTED	TEMP	Note #
1			3		
2			4		

(*Any additional anti-freeze system results will be listed in Note # Section)



2760 Beverly Dr.
Suite 9
Aurora, IL 60502
630.506.5535
www.allegiantfire.net

Report to: U.S. Fire & Safety Equipment Company
Property: WCC, Building A, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL **Zip:** 60554

Date: 10/13/2021
Job Number: 23057292
Technician: Michael Messacar, Jason Brut

Annual FIRE SPRINKLER INSPECTION REPORT

<i>FIVE YEAR REQUIREMENTS</i>	YES	NO	N/A	Note #
Have all Check Valves, Pre-action or Deluge Valves been internally inspected within the last 5 years?	☐	☒	☐	NA
Has the piping in all systems been checked for obstructive materials within the last 5 years?	☐	☒	☐	NA
System Gauges tested or replaced within the last 5 years?	☒	☐	☐	2018

<i>CONTROL VALVES</i>	YES	NO	N/A	Note #
All Control Valves in the correct (open or closed) position?	☒	☐	☐	
Locked or supervised?	☒	☐	☐	
Easily accessible?	☒	☐	☐	
Free from damage or leaks?	☒	☐	☐	
Proper signage in place?	☒	☐	☐	
Tamper Switches operate properly?	☒	☐	☐	
All Control Valves operated through full range and return to normal position?	☒	☐	☐	
OS&Y Valves properly lubricated?	☒	☐	☐	

<i>Description</i>	<i>Type</i>	<i>Size</i>	<i>Location</i>	<i>Note #</i>
System before backflow	Ball Valve	2"	Electric / Storage -141	
System after backflow	Ball Valve	2"	Electric / Storage -141	

(*Any additional control valves will be listed on a separate sheet.)

<i>MAIN DRAIN AND WATERFLOW TEST RESULTS</i>	YES	NO	N/A	Note #
Do main drain test results differ more than 10% from previous test?	☐	☒	☐	

<i>System #</i>	<i>Riser Size</i>	<i>Size of Test Pipe</i>	<i>PSI Static Pressure Before</i>	<i>PSI Residual Pressure</i>	<i>PSI Pressure After</i>	<i>Waterflow Time (sec)</i>	<i>Note #</i>
Riser	2"	1"	95	60	80	W/60	Manual only

(*Any additional main drain/waterflow results will be listed on a separate sheet.)

Date: 10/13/2021
Job Number: 23057292
Technician:
Michael Messacar, Jason Brut

THE INSPECTOR SUGGESTS THE FOLLOWING NECESSARY IMPROVEMENTS:
(these suggestions are not the result of an engineering survey)

[illegible]

INSPECTION & SUGGESTED IMPROVEMENTS WERE DISCUSSED WITH THE UNDERSIGNED OWNER OR OWNERS REPRESENTATIVE:
By this signature, I certify: I state that the information on this form is correct at the time and place of my inspection, and that all equipment tested now was left in operational condition upon completion of this inspection except as noted in comments above.

Verbal checkout with Laura

OWNER / REPRESENTATIVE SIGNATURE

Verbal checkout with Laura

PRINT NAME _____

10/13/2021

DATE _____

INSPECTOR SIGNATURE

Michael Messacar, Jason Brut

PRINT NAME

149731

NICET #



2760 Beverly Dr.
Suite 9
Aurora, IL 60502
630.506.5535
www.allegiantfire.net

Report to: U.S. Fire & Safety Equipment Company
Property: WCC, Ceramics Building, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL **Zip:** 60554

Date: 10/13/2021
Job Number: 23057294
Technician: Michael Messacar, Jason Brut

Annual FIRE SPRINKLER INSPECTION REPORT

Central Station	Customer	POS/Acct	Takes out	Out	Of	IN	Service
-----------------	----------	----------	-----------	-----	----	----	---------

GENERAL	YES	NO	N/A	Note #
Is the building currently occupied?	☒	☐	☐	
Has the occupancy classification and hazard of contents remained the same since the last inspection?	☒	☐	☐	
Are all fire protection systems in service?	☒	☐	☐	
Has the system remained in service without modifications or actuations of devices/alarms since last inspection?	☒	☐	☐	
Fire pump onsite?	☐	☒	☐	

SPRINKLERS (visible)	YES	NO	N/A	Note #
Free of damage or leaks?	☒	☐	☐	
Free of corrosion, foreign material, or paint, loading?	☒	☐	☐	
Installed in proper orientation?	☒	☐	☐	
Fluid in glass bulbs?	☒	☐	☐	
Spare head box contains proper number and type of heads, including wrench(s)?	☒	☐	☐	
Escutcheon plates are present and installed correctly?	☒	☐	☐	
Minimum clearance between sprinklers and storage?	☒	☐	☐	
Sprinklers tested or replaced per appropriate testing schedule?	☒	☐	☐	

Sprinkler heads in use and earliest date on heads:

Standard: _____ Quick Response: _____ ESFR: _____ Dry Pendant: ☒ 2013 _____

PIPING	YES	NO	N/A	Note #
In good condition with no external corrosion?	☒	☐	☐	
No leaks or mechanical damage?	☒	☐	☐	
Correct alignment/No external loads?	☒	☐	☐	
Wet Sprinkler piping not exposed to freezing temperatures?	☒	☐	☐	
Hangers/bracing not damaged or loose?	☒	☐	☐	

FIRE DEPARTMENT CONNECTIONS	YES	NO	N/A	Note #
Visible and accessible?	☒	☐	☐	
Couplings swivel and operate properly?	☒	☐	☐	
Plugs or caps in place?	☒	☐	☐	
Identification signs are in place?	☒	☐	☐	
Ball drip valve is functional/not leaking?	☒	☐	☐	

ANTI-FREEZE SYSTEMS	YES	NO	N/A	Note #
Have all anti-freeze systems been tested?	☐	☐	☒	
Proper signage and placard info in place?	☐	☐	☒	

LOCATION / AREA PROTECTED	TEMP	Note #	LOCATION / AREA PROTECTED	TEMP	Note #
1			3		
2			4		

(*Any additional anti-freeze system results will be listed in Note # Section)



2760 Beverly Dr.
Suite 9
Aurora, IL 60502
630.506.5535
www.allegiantfire.net

Report to: U.S. Fire & Safety Equipment Company
Property: WCC, Ceramics Building, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL **Zip:** 60554

Date: 10/13/2021
Job Number: 23057294
Technician: Michael Messacar, Jason Brut

Annual FIRE SPRINKLER INSPECTION REPORT

<i>FIVE YEAR REQUIREMENTS</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
Have all Check Valves, Pre-action or Deluge Valves been internally inspected within the last 5 years?	☒	☐	☐	2018
Has the piping in all systems been checked for obstructive materials within the last 5 years?	☒	☐	☐	2018
System Gauges tested or replaced within the last 5 years?	☒	☐	☐	2018

<i>CONTROL VALVES</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
All Control Valves in the correct (open or closed) position?	☒	☐	☐	
Locked or supervised?	☒	☐	☐	
Easily accessible?	☒	☐	☐	
Free from damage or leaks?	☒	☐	☐	
Proper signage in place?	☒	☐	☐	
Tamper Switches operate properly?	☒	☐	☐	
All Control Valves operated through full range and return to normal position?	☒	☐	☐	
OS&Y Valves properly lubricated?	☒	☐	☐	

<i>Description</i>	<i>Type</i>	<i>Size</i>	<i>Location</i>	<i>Note #</i>
System before backflow	Butterfly	4"	Sprinkler room - SW corner	
System after backflow	Butterfly	4"	Sprinkler room - SW corner	
Sectional for dry	Butterfly	3"	Sprinkler room - SW corner	

(*Any additional control valves will be listed on a separate sheet.)

<i>MAIN DRAIN AND WATERFLOW TEST RESULTS</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
Do main drain test results differ more than 10% from previous test?	☐	☒	☐	

<i>System #</i>	<i>Riser Size</i>	<i>Size of Test Pipe</i>	<i>PSI Static Pressure Before</i>	<i>PSI Residual Pressure</i>	<i>PSI Pressure After</i>	<i>Waterflow Time (sec)</i>	<i>Note #</i>
Dry	3"	1 1/2"	70	60	70	NA	

(*Any additional main drain/waterflow results will be listed on a separate sheet.)



2760 Beverly Dr.
Suite 9
Aurora, IL 60502
630.506.5535
www.allegiantfire.net

Report to: U.S. Fire & Safety Equipment Company
Property: WCC, Ceramics Building, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL
Zip: 60554

Date: 10/13/2021
Job Number: 23057294
Technician: Michael Messacar, Jason Brut

Annual FIRE SPRINKLER INSPECTION REPORT

*THE INSPECTOR SUGGESTS THE FOLLOWING NECESSARY IMPROVEMENTS:
(these suggestions are not the result of an engineering survey)*

Note #

MODIFICATIONS OR CORRECTIONS MADE DURING THIS INSPECTION:

INSPECTION & SUGGESTED IMPROVEMENTS WERE DISCUSSED WITH THE UNDERSIGNED OWNER OR OWNERS REPRESENTATIVE:
By this signature, I certify: I state that the information on this form is correct at the time and place of my inspection, and that all equipment tested now was left in operational condition upon completion of this inspection except as noted in comments above.

Verbal checkout with Brian

OWNER / REPRESENTATIVE SIGNATURE

Verbal checkout with Brian
PRINT NAME

10/13/2021
DATE

INSPECTOR SIGNATURE

Michael Messacar, Jason Brut
PRINT NAME

149731
NICET #



2760 Beverly Dr.
Suite 9
Aurora, IL 60502
630.506.5535
www.allegiantfire.net

Report to: U.S. Fire & Safety Equipment Company
Property: WCC, Ceramics Building, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL **Zip:** 60554

Date: 10/13/2021
Job Number: 23057294
Technician: Michael Messacar, Jason Brut

DRY VALVE TRIP TEST REPORT

Dry Pipe Valves		System #	System #	System #	System #
		Sprinkler room - SW corner			
Manufacturer		Viking			
Valve Model		F-2			
Valve Size		3"			
Valve Serial Number		W605749			
Controlling Sprinklers	(Location)	Thru out			
	(Number)	All			
Date Last Trip Tested or Operated		2020			
Pressure Before Test	Air	25			
	Water	90			
Size and Location of Test Valve		1 1/2"			
Was Valve Below Dry Valve Open Wide at Test?		YES NO	YES NO	YES NO	YES NO
		☐ ☒	☐ ☐	☐ ☐	☐ ☐
(If not, how many turns?)		4			
Tripped at	Air Pressure	6 psi			
	Water Pressure	70			
	Time	15 seconds			
If System Flooded, Time Water Reached Test Opening		NA			
Performance					
Condition of	Interior of Body	Satisfactory			
	Moving Parts	Satisfactory			
	Rubber Facing	Satisfactory			
	Seats	Satisfactory			
		YES NO	YES NO	YES NO	YES NO
Did Valve Reset?		☒ ☐	☐ ☐	☐ ☐	☐ ☐
Did Alarms Operate at Trip Test?		☒ ☐	☐ ☐	☐ ☐	☐ ☐
Did Low Air Alarm Operate Properly?		☒ ☐	☐ ☐	☐ ☐	☐ ☐
If yes, at:		15 psi			
All Auxiliary Drains Blown Out?		☒ ☐	☐ ☐	☐ ☐	☐ ☐
Water Control Valve Left Open?		☒ ☐	☐ ☐	☐ ☐	☐ ☐
Alarm Control Valve Left Open?		☒ ☐	☐ ☐	☐ ☐	☐ ☐
When Was Last 3-Year Full Flood Trip Test Performed?		NA			



2760 Beverly Dr.
Suite 9
Aurora, IL 60502
630.506.5535
www.allegiantfire.net

Report to: U.S. Fire & Safety Equipment Company
Property: WCC, Ceramics Building, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL
Zip: 60554

Date: 10/13/2021
Job Number: 23057294
Technician: Michael Messacar, Jason Brut

DRY VALVE TRIP TEST REPORT

Quick Opening Devices										
Manufacturer	NA									
Type	NA									
Model	NA									
Device Serial Number	NA									
Air Pressure in Upper Chamber	NA									
Quick Opening Device Tripped at	NA	SEC	NA	LBS	SEC	LBS	SEC	LBS	SEC	LBS
Quick Opening Device Left in Service and Control Valve Left Opened?	YES	NO	YES	NO	YES	NO	YES	NO	YES	NO
	☒	☐	☐	☐	☐	☐	☐	☐	☐	☐

LOW POINT DRAIN LIST								
LOCATION	Drained		Note #	LOCATION	Drained		Note #	
	YES	NO			YES	NO		
ITV	☒	☐			☐	☐		
DPV	☒	☐			☐	☐		
	☐	☐			☐	☐		
	☐	☐			☐	☐		
	☐	☐			☐	☐		
	☐	☐			☐	☐		
	☐	☐			☐	☐		
	☐	☐			☐	☐		
	☐	☐			☐	☐		
	☐	☐			☐	☐		
	☐	☐			☐	☐		

Note #	THE INSPECTOR SUGGESTS THE FOLLOWING NECESSARY IMPROVEMENTS: (these suggestions are not the result of an engineering survey)

Customer Requirements

- * Building Owner is responsible for providing adequate heat (40°F or greater) in all areas where wet-pipe sprinklers are installed.
- * Building Owner is responsible for draining all low points of water condensation frequently. All low point drains must be in a fully heated area and free of debris.
- * The dry pipe valve and components must be in a fully heated area at all times. There should be power to the air compressor at all times. Circuit breakers should be checked frequently for blown fuses. Air compressor should be checked for proper oil type and quantity. Air compressor should be on its own dedicated circuit with a locked on switch in the breaker (not a toggle switch on the wall).
- * An internal pipe examination should be performed every five (5) years.
- * Accurate Zone Maps are required on all dry systems with all low points clearly marked.
- * In the event of a low air alarm, immediate action is required.

Customer Acknowledgement _____

			Jason Brut	149731
INSPECTOR SIGNATURE			PRINT NAME	NICET #

10/16/2021

Property: WCC, A&P, 4 IL-47
 Address: 4 Illinois 47
 City: Sugar Grove
 State: IL Zip: 60554

Job Number:
 Technician:

Annual FIRE SPRINKLER INSPECTION REPORT

Central Station	POS/Acct	Handled by customer	Out	IN
-----------------	----------	---------------------	-----	----

GENERAL	YES	NO	N/A	Note #
Is the building currently occupied?	☒	☐	☐	
Has the occupancy classification and hazard of contents remained the same since the last inspection?	☒	☐	☐	
Are all fire protection systems in service?	☒	☐	☐	
Has the system remained in service without modifications or actuations of devices/alarms since last inspection?	☒	☐	☐	
Fire pump onsite?	☒	☐	☐	

SPRINKLERS (visible)	YES	NO	N/A	Note #
Free of damage or leaks?	☒	☐	☐	
Free of corrosion, foreign material, or paint, loading?	☒	☐	☐	
Installed in proper orientation?	☒	☐	☐	
Fluid in glass bulbs?	☒	☐	☐	
Spare head box contains proper number and type of heads, including wrench(s)?	☒	☐	☐	
Escutcheon plates are present and installed correctly?	☒	☐	☐	
Minimum clearance between sprinklers and storage?	☒	☐	☐	
Sprinklers tested or replaced per appropriate testing schedule?	☒	☐	☐	

Sprinkler heads in use and earliest date on heads:

Standard: ☒ 2002 Quick Response: _____ ESFR: _____ Dry Pendant: _____

PIPING	YES	NO	N/A	Note #
In good condition with no external corrosion?	☒	☐	☐	
No leaks or mechanical damage?	☒	☐	☐	
Correct alignment/No external loads?	☒	☐	☐	
Wet Sprinkler piping not exposed to freezing temperatures?	☒	☐	☐	
Hangers/bracing not damaged or loose?	☒	☐	☐	

FIRE DEPARTMENT CONNECTIONS	YES	NO	N/A	Note #
Visible and accessible?	☒	☐	☐	
Couplings swivel and operate properly?	☒	☐	☐	
Plugs or caps in place?	☒	☐	☐	
Identification signs are in place?	☒	☐	☐	
Ball drip valve is functional/not leaking?	☒	☐	☐	

ANTI-FREEZE SYSTEMS	YES	NO	N/A	Note #
Have all anti-freeze systems been tested?	☐	☐	☒	
Proper signage and placard info in place?	☐	☐	☒	

LOCATION / AREA PROTECTED	TEMP	Note #	LOCATION / AREA PROTECTED	TEMP	Note #
1			3		
2			4		

(*Any additional anti-freeze system results will be listed in Note # Section)

Report to:
Property: WCC, A&P, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL **Zip:** 60554

Date: 10/16/2021
Job Number:
Technician:

Annual FIRE SPRINKLER INSPECTION REPORT

<i>FIVE YEAR REQUIREMENTS</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
Have all Check Valves, Pre-action or Deluge Valves been internally inspected within the last 5 years?	☒	☐	☐	2019
Has the piping in all systems been checked for obstructive materials within the last 5 years?	☒	☐	☐	2019
System Gauges tested or replaced within the last 5 years?	☒	☐	☐	2018

<i>CONTROL VALVES</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
All Control Valves in the correct (open or closed) position?	☒	☐	☐	
Locked or supervised?	☒	☐	☐	
Easily accessible?	☒	☐	☐	
Free from damage or leaks?	☒	☐	☐	
Proper signage in place?	☒	☐	☐	
Tamper Switches operate properly?	☒	☐	☐	
All Control Valves operated through full range and return to normal position?	☒	☐	☐	
OS&Y Valves properly lubricated?	☒	☐	☐	

<i>Description</i>	<i>Type</i>	<i>Size</i>	<i>Location</i>	<i>Note #</i>
Before Backflow	OS&Y	4"	Mech Room 115A	
After Backflow	OS&Y	4"	Mech Room 115A	
System 1	Butterfly	3"	Mech Room 115A	
System 2	Butterfly	3"	Mech Room 115A	

(*Any additional control valves will be listed on a separate sheet.)

<i>MAIN DRAIN AND WATERFLOW TEST RESULTS</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
Do main drain test results differ more than 10% from previous test?	☐	☒	☐	

<i>System #</i>	<i>Riser Size</i>	<i>Size of Test Pipe</i>	<i>PSI Static Pressure Before</i>	<i>PSI Residual Pressure</i>	<i>PSI Pressure After</i>	<i>Waterflow Time (sec)</i>	<i>Note #</i>
System 1	3"	2"	70	45	55	W/60	
System 2	3"	2"	70	45	55	W/60	
Main	4"	2"	70	45	55	W/60	

(*Any additional main drain/waterflow results will be listed on a separate sheet.)

Sprinkler Inspection

Report # SPI(C) - 188515

General Information

Service Provider:	Allegiant Fire Protection LLC	SP ID:	SP11855
Customer Account #:	--	Address:	2760 Beverly Dr., Suite 9 Aurora Illinois 60503
Phone:	630-506-5535	Fax:	--
General Email:	jthibodeau@allegiantfire.net		
Report Entered By:	Kaitlin Moore	User's Email:	kmoore@allegiantfire.net
SP Lead Technician:	Jason Brut	Date Inspection Completed:	10/13/2021
Lead Tech Nicet #:	149731		
Other License #:	--	Other License Type:	--

Primary AHJ's Name:	Sugar Grove Fire Protection District	Primary AHJ ID:	ILA11126
AHJ Inspector Name:	--	AHJ Inspector Badge#:	--
Primary AHJ Phone:	630-466-4513	Primary AHJ Email:	wpardon@sugargrovecfire.com
Secondary AHJ's Name:	--	Secondary AHJ ID:	--
Secondary AHJ Phone:	--	Secondary AHJ Email:	--

PO ID:	--		
Business Occupant:	WAUBONSEE COMMUNITY COLLEGE		
Region:	No Region	Location:	4S783 - State Route 47 - #Auditorium
Number :	4S783	Street Prefix :	--
Street Name :	State Route 47	Unit # :	Auditorium
City:	Sugar Grove	State:	Illinois
Zip:	60554	Phone:	630-466-7900
Contact Name:	Edward Plante		
Contact Phone:	630-466-7900	Contact Email :	eplante@waubonsee.edu
PIN#:	--	Classification:	--

Alternate PO Details			
Alternate PO ID:	--	Contact Name:	--
Contact Phone:	--	Contact Email :	--

Attach Report

Report:	SPI - Sprinkler System Inspection
Frequency:	Annual
Attachment:	There is a supplemental file for this report that is not available in PDF view. Please visit inspectionreportsonline.net to access that file.
Next Inspection Due Date:	October - 2022
Report Completed By:	--
Email Sent To:	eplante@waubonsee.edu

Notes

Entered By	Notes Type	Date	Note

Test performed in accordance with the following code or standard:

Report to:
Property: WCC, Auditorium, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL Zip: 60554

Date: 10/13/2021
Job Number:
Technician:

Annual FIRE SPRINKLER INSPECTION REPORT

Central Station	Customer takes	POS/Acct	Out	Out	Of	IN	Service
-----------------	----------------	----------	-----	-----	----	----	---------

GENERAL	YES	NO	N/A	Note #
Is the building currently occupied?	☒	☐	☐	
Has the occupancy classification and hazard of contents remained the same since the last inspection?	☒	☐	☐	
Are all fire protection systems in service?	☒	☐	☐	
Has the system remained in service without modifications or actuations of devices/alarms since last inspection?	☒	☐	☐	
Fire pump onsite?	☐	☒	☐	

SPRINKLERS (visible)	YES	NO	N/A	Note #
Free of damage or leaks?	☒	☐	☐	
Free of corrosion, foreign material, or paint, loading?	☒	☐	☐	
Installed in proper orientation?	☒	☐	☐	
Fluid in glass bulbs?	☒	☐	☐	
Spare head box contains proper number and type of heads, including wrench(s)?	☒	☐	☐	
Escutcheon plates are present and installed correctly?	☒	☐	☐	
Minimum clearance between sprinklers and storage?	☒	☐	☐	
Sprinklers tested or replaced per appropriate testing schedule?	☒	☐	☐	

Sprinkler heads in use and earliest date on heads:

Standard: ☒ 2004 Quick Response: _____ ESFR: _____ Dry Pendant: _____

PIPING	YES	NO	N/A	Note #
In good condition with no external corrosion?	☒	☐	☐	
No leaks or mechanical damage?	☒	☐	☐	
Correct alignment/No external loads?	☒	☐	☐	
Wet Sprinkler piping not exposed to freezing temperatures?	☒	☐	☐	
Hangers/bracing not damaged or loose?	☒	☐	☐	

FIRE DEPARTMENT CONNECTIONS	YES	NO	N/A	Note #
Visible and accessible?	☒	☐	☐	
Couplings swivel and operate properly?	☒	☐	☐	
Plugs or caps in place?	☒	☐	☐	
Identification signs are in place?	☒	☐	☐	
Ball drip valve is functional/not leaking?	☒	☐	☐	

ANTI-FREEZE SYSTEMS	YES	NO	N/A	Note #
Have all anti-freeze systems been tested?	☐	☐	☒	
Proper signage and placard info in place?	☐	☐	☒	

LOCATION / AREA PROTECTED	TEMP	Note #	LOCATION / AREA PROTECTED	TEMP	Note #
1			3		
2			4		

(*Any additional anti-freeze system results will be listed in Note # Section)

Report to:
Property: WCC, Auditorium, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL **Zip:** 60554

Date: 10/13/2021
Job Number:
Technician:

Annual FIRE SPRINKLER INSPECTION REPORT

<i>FIVE YEAR REQUIREMENTS</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
Have all Check Valves, Pre-action or Deluge Valves been internally inspected within the last 5 years?	☒	☐	☐	2018
Has the piping in all systems been checked for obstructive materials within the last 5 years?	☒	☐	☐	2018
System Gauges tested or replaced within the last 5 years?	☒	☐	☐	2018

<i>CONTROL VALVES</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
All Control Valves in the correct (open or closed) position?	☒	☐	☐	
Locked or supervised?	☒	☐	☐	
Easily accessible?	☒	☐	☐	
Free from damage or leaks?	☒	☐	☐	
Proper signage in place?	☒	☐	☐	
Tamper Switches operate properly?	☒	☐	☐	
All Control Valves operated through full range and return to normal position?	☒	☐	☐	
OS&Y Valves properly lubricated?	☒	☐	☐	

<i>Description</i>	<i>Type</i>	<i>Size</i>	<i>Location</i>	<i>Note #</i>
Before Backflow	OS&Y	3"	Sprinkler Room	
After Backflow	OS&Y	3"	Sprinkler Room	

(*Any additional control valves will be listed on a separate sheet.)

<i>MAIN DRAIN AND WATERFLOW TEST RESULTS</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
Do main drain test results differ more than 10% from previous test?	☐	☒	☐	

<i>System #</i>	<i>Riser Size</i>	<i>Size of Test Pipe</i>	<i>PSI Static Pressure Before</i>	<i>PSI Residual Pressure</i>	<i>PSI Pressure After</i>	<i>Waterflow Time (sec)</i>	<i>Note #</i>
Riser 1	3"	2"	75	55	65	W/60	

(*Any additional main drain/waterflow results will be listed on a separate sheet.)

Report to:
Property: WCC, Aurora, 18 S River St
Address: 18 South River Street
City: Aurora
State: IL **Zip:** 60506

Date: 10/23/2021
Job Number:
Technician: T

Annual FIRE SPRINKLER INSPECTION REPORT

Central Station	POS/Acct	Handled by customer	Out	IN
-----------------	----------	---------------------	-----	----

GENERAL	YES	NO	N/A	Note #
Is the building currently occupied?	☒	☐	☐	
Has the occupancy classification and hazard of contents remained the same since the last inspection?	☒	☐	☐	
Are all fire protection systems in service?	☒	☐	☐	
Has the system remained in service without modifications or actuations of devices/alarms since last inspection?	☒	☐	☐	
Fire pump onsite?	☐	☒	☐	

SPRINKLERS (visible)	YES	NO	N/A	Note #
Free of damage or leaks?	☒	☐	☐	
Free of corrosion, foreign material, or paint, loading?	☒	☐	☐	
Installed in proper orientation?	☒	☐	☐	
Fluid in glass bulbs?	☒	☐	☐	
Spare head box contains proper number and type of heads, including wrench(s)?	☒	☐	☐	
Escutcheon plates are present and installed correctly?	☒	☐	☐	
Minimum clearance between sprinklers and storage?	☒	☐	☐	
Sprinklers tested or replaced per appropriate testing schedule?	☒	☐	☐	

Sprinkler heads in use and earliest date on heads:

Standard: _____ Quick Response: ☒ 2009 ESFR: _____ Dry Pendant: _____

PIPING	YES	NO	N/A	Note #
In good condition with no external corrosion?	☒	☐	☐	
No leaks or mechanical damage?	☒	☐	☐	
Correct alignment/No external loads?	☒	☐	☐	
Wet Sprinkler piping not exposed to freezing temperatures?	☒	☐	☐	
Hangers/bracing not damaged or loose?	☒	☐	☐	

FIRE DEPARTMENT CONNECTIONS	YES	NO	N/A	Note #
Visible and accessible?	☒	☐	☐	
Couplings swivel and operate properly?	☒	☐	☐	
Plugs or caps in place?	☒	☐	☐	
Identification signs are in place?	☒	☐	☐	
Ball drip valve is functional/not leaking?	☒	☐	☐	

ANTI-FREEZE SYSTEMS	YES	NO	N/A	Note #
Have all anti-freeze systems been tested?	☐	☐	☒	
Proper signage and placard info in place?	☐	☐	☒	

LOCATION / AREA PROTECTED	TEMP	Note #	LOCATION / AREA PROTECTED	TEMP	Note #
1			3		
2			4		

(*Any additional anti-freeze system results will be listed in Note # Section)

Report to:
Property: WCC, Aurora, 18 S River St
Address: 18 South River Street
City: Aurora
State: IL **Zip:** 60506

Date: 10/23/2021
Job Number:
Technician:

Annual FIRE SPRINKLER INSPECTION REPORT

5-water gauges, 1 compound gauge)

<i>FIVE YEAR REQUIREMENTS</i>	YES	NO	N/A	Note #
Have all Check Valves, Pre-action or Deluge Valves been internally inspected within the last 5 years?	☐	☒	☐	1
Has the piping in all systems been checked for obstructive materials within the last 5 years?	☐	☒	☐	1
System Gauges tested or replaced within the last 5 years?	☐	☒	☐	2

<i>CONTROL VALVES</i>	YES	NO	N/A	Note #
All Control Valves in the correct (open or closed) position?	☒	☐	☐	
Locked or supervised?	☒	☐	☐	
Easily accessible?	☒	☐	☐	
Free from damage or leaks?	☒	☐	☐	
Proper signage in place?	☒	☐	☐	
Tamper Switches operate properly?	☒	☐	☐	
All Control Valves operated through full range and return to normal position?	☒	☐	☐	
OS&Y Valves properly lubricated?	☒	☐	☐	

<i>Description</i>	<i>Type</i>	<i>Size</i>	<i>Location</i>	<i>Note #</i>
City 1	OS&Y	8	Sprinkler room	
City 2	OS&Y	8	Sprinkler room	
Fire pump suction	OS&Y	8	Sprinkler room	
Fire pump discharge	OS&Y	8	Sprinkler room	
Main riser	Butterfly	6"	Sprinkler room	
Bypass 1	Butterfly	6"	Sprinkler room	
Bypass 2	Butterfly	6"	Sprinkler room	
4th Floor	Butterfly	2"	4th Floor Center Stairwell	
2nd Floor	Butterfly	2 1/2"	2nd Floor Center Stairwell	
Fire pump test header	OS&Y	6"	Sprinkler room	

(*Any additional control valves will be listed on a separate sheet.)

<i>MAIN DRAIN AND WATERFLOW TEST RESULTS</i>	YES	NO	N/A	Note #
Do main drain test results differ more than 10% from previous test?	☐	☒	☐	

<i>System #</i>	<i>Riser Size</i>	<i>Size of Test Pipe</i>	<i>PSI Static Pressure Before</i>	<i>PSI Residual Pressure</i>	<i>PSI Pressure After</i>	<i>Waterflow Time (sec)</i>	<i>Note #</i>
First floor riser	4"	2"	70	65	70	W/60	
Main riser feed	6"	2"	70	65	70	W/60	
4th Floor	2"	1 1/4"	70	65	70	W/60	
3rd Floor	2"	1 1/4"	70	65	70	W/60	
2nd Floor	2 1/2"	1 1/4"	70	65	70	W/60	

(*Any additional main drain/waterflow results will be listed on a separate sheet.)

Report to:
Property: WCC, Building A, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL **Zip:** 60554

Date: 10/13/2021
Job Number:
Technician:

Annual FIRE SPRINKLER INSPECTION REPORT

Central Station	Customer takes	POS/Acct	Out	Out	Of	IN	Service
-----------------	----------------	----------	-----	-----	----	----	---------

GENERAL	YES	NO	N/A	Note #
Is the building currently occupied?	☒	☐	☐	
Has the occupancy classification and hazard of contents remained the same since the last inspection?	☒	☐	☐	
Are all fire protection systems in service?	☒	☐	☐	
Has the system remained in service without modifications or actuations of devices/alarms since last inspection?	☒	☐	☐	
Fire pump onsite?	☐	☒	☐	

SPRINKLERS (visible)	YES	NO	N/A	Note #
Free of damage or leaks?	☒	☐	☐	
Free of corrosion, foreign material, or paint, loading?	☒	☐	☐	
Installed in proper orientation?	☒	☐	☐	
Fluid in glass bulbs?	☒	☐	☐	
Spare head box contains proper number and type of heads, including wrench(s)?	☒	☐	☐	
Escutcheon plates are present and installed correctly?	☒	☐	☐	
Minimum clearance between sprinklers and storage?	☒	☐	☐	
Sprinklers tested or replaced per appropriate testing schedule?	☒	☐	☐	

Sprinkler heads in use and earliest date on heads:

Standard: ☒ 2000 Quick Response: _____ ESFR: _____ Dry Pendant: _____

PIPING	YES	NO	N/A	Note #
In good condition with no external corrosion?	☒	☐	☐	
No leaks or mechanical damage?	☒	☐	☐	
Correct alignment/No external loads?	☒	☐	☐	
Wet Sprinkler piping not exposed to freezing temperatures?	☒	☐	☐	
Hangers/bracing not damaged or loose?	☒	☐	☐	

FIRE DEPARTMENT CONNECTIONS	YES	NO	N/A	Note #
Visible and accessible?	☒	☐	☐	
Couplings swivel and operate properly?	☒	☐	☐	
Plugs or caps in place?	☒	☐	☐	
Identification signs are in place?	☒	☐	☐	
Ball drip valve is functional/not leaking?	☒	☐	☐	

ANTI-FREEZE SYSTEMS	YES	NO	N/A	Note #
Have all anti-freeze systems been tested?	☐	☐	☒	
Proper signage and placard info in place?	☐	☐	☒	

LOCATION / AREA PROTECTED	TEMP	Note #	LOCATION / AREA PROTECTED	TEMP	Note #
1			3		
2			4		

(*Any additional anti-freeze system results will be listed in Note # Section)

Report to:
Property: WCC, Building A, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL **Zip:** 60554

Date: 10/13/2021
Job Number:
Technician:

Annual FIRE SPRINKLER INSPECTION REPORT

<i>FIVE YEAR REQUIREMENTS</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
Have all Check Valves, Pre-action or Deluge Valves been internally inspected within the last 5 years?	☐	☒	☐	NA
Has the piping in all systems been checked for obstructive materials within the last 5 years?	☐	☒	☐	NA
System Gauges tested or replaced within the last 5 years?	☒	☐	☐	2018

<i>CONTROL VALVES</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
All Control Valves in the correct (open or closed) position?	☒	☐	☐	
Locked or supervised?	☒	☐	☐	
Easily accessible?	☒	☐	☐	
Free from damage or leaks?	☒	☐	☐	
Proper signage in place?	☒	☐	☐	
Tamper Switches operate properly?	☒	☐	☐	
All Control Valves operated through full range and return to normal position?	☒	☐	☐	
OS&Y Valves properly lubricated?	☒	☐	☐	

<i>Description</i>	<i>Type</i>	<i>Size</i>	<i>Location</i>	<i>Note #</i>
System before backflow	Ball Valve	2"	Electric / Storage -141	
System after backflow	Ball Valve	2"	Electric / Storage -141	

(*Any additional control valves will be listed on a separate sheet.)

<i>MAIN DRAIN AND WATERFLOW TEST RESULTS</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
Do main drain test results differ more than 10% from previous test?	☐	☒	☐	

<i>System #</i>	<i>Riser Size</i>	<i>Size of Test Pipe</i>	<i>PSI Static Pressure Before</i>	<i>PSI Residual Pressure</i>	<i>PSI Pressure After</i>	<i>Waterflow Time (sec)</i>	<i>Note #</i>
Riser	2"	1"	95	60	80	W/60	Manual only

(*Any additional main drain/waterflow results will be listed on a separate sheet.)

Sprinkler Inspection

Report # SPI(C) - 188513

General Information

Service Provider:	Allegiant Fire Protection LLC	SP ID:	SP11855
Customer Account #:	--	Address:	2760 Beverly Dr., Suite 9 Aurora Illinois 60503
Phone:	630-506-5535	Fax:	--
General Email:	jthibodeau@allegiantfire.net		
Report Entered By:	Kaitlin Moore	User's Email:	kmoore@allegiantfire.net
SP Lead Technician:	Jason Brut	Date Inspection Completed:	10/13/2021
Lead Tech Nicet #:	149731		
Other License #:	--	Other License Type:	--

Primary AHJ's Name:	Sugar Grove Fire Protection District	Primary AHJ ID:	ILA11126
AHJ Inspector Name:	--	AHJ Inspector Badge#:	--
Primary AHJ Phone:	630-466-4513	Primary AHJ Email:	wpardon@sugargrovecfire.com
Secondary AHJ's Name:	--	Secondary AHJ ID:	--
Secondary AHJ Phone:	--	Secondary AHJ Email:	--

PO ID:	--		
Business Occupant:	WAUBONSEE COMMUNITY COLLEGE		
Region:	No Region	Location:	4S783 - State Route 47 - #BUILDING A
Number :	4S783	Street Prefix :	--
Street Name :	State Route 47	Unit # :	BUILDING A
City:	Sugar Grove	State:	Illinois
Zip:	60554	Phone:	630-466-7900
Contact Name:	Edward Plante		
Contact Phone:	630-466-7900	Contact Email :	eplante@waubonsee.edu
PIN#:	--	Classification:	--

Alternate PO Details			
Alternate PO ID:	--	Contact Name:	--
Contact Phone:	--	Contact Email :	--

Attach Report

Report:	SPI - Sprinkler System Inspection
Frequency:	Annual
Attachment:	There is a supplemental file for this report that is not available in PDF view. Please visit inspectionreportsonline.net to access that file.
Next Inspection Due Date:	October - 2022
Report Completed By:	--
Email Sent To:	eplante@waubonsee.edu

Notes

Entered By	Notes Type	Date	Note
Kaitlin Moore	New Deficiency	10/15/2021	System due for 5 year internal inspection and FDC hydro
Kaitlin Moore	New Deficiency	10/15/2021	could not gain access to room with ITV

Test performed in accordance with the following code or standard:

Sprinkler Inspection

Report # SPI(C) - 188511

General Information

Service Provider:	Allegiant Fire Protection LLC	SP ID:	SP11855
Customer Account #:	--	Address:	2760 Beverly Dr., Suite 9 Aurora Illinois 60503
Phone:	630-506-5535	Fax:	--
General Email:	jthibodeau@allegiantfire.net		
Report Entered By:	Kaitlin Moore	User's Email:	kmoore@allegiantfire.net
SP Lead Technician:	Jason Brut	Date Inspection Completed:	10/13/2021
Lead Tech Nicet #:	149731		
Other License #:	--	Other License Type:	--

Primary AHJ's Name:	Sugar Grove Fire Protection District	Primary AHJ ID:	ILA11126
AHJ Inspector Name:	--	AHJ Inspector Badge#:	--
Primary AHJ Phone:	630-466-4513	Primary AHJ Email:	wparson@sugargrovecfire.com
Secondary AHJ's Name:	--	Secondary AHJ ID:	--
Secondary AHJ Phone:	--	Secondary AHJ Email:	--

PO ID:	--		
Business Occupant:	WAUBONSEE COMMUNITY COLLEGE		
Region:	No Region	Location:	4S783 - State Route 47 - #CERAMICS BUILDING
Number :	4S783	Street Prefix :	--
Street Name :	State Route 47	Unit # :	CERAMICS BUILDING
City:	Sugar Grove	State:	Illinois
Zip:	60554	Phone:	630-466-7900
Contact Name:	EDWARD PLANTE		
Contact Phone:	630-466-7900	Contact Email :	eplante@waubonsee.edu
PIN#:	--	Classification:	--

Alternate PO Details			
Alternate PO ID:	--	Contact Name:	--
Contact Phone:	--	Contact Email :	--

Attach Report

Report:	SPI - Sprinkler System Inspection
Frequency:	Annual
Attachment:	There is a supplemental file for this report that is not available in PDF view. Please visit inspectionreportsonline.net to access that file.
Next Inspection Due Date:	October - 2022
Report Completed By:	--
Email Sent To:	eplante@waubonsee.edu

Notes

Entered By	Notes Type	Date	Note

Test performed in accordance with the following code or standard:

Report to:
Property: WCC, Ceramics Building, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL **Zip:** 60554

Date: 10/13/2021
Job Number:
Technician:

Annual FIRE SPRINKLER INSPECTION REPORT

Central Station	Customer	POS/Acct	Takes out	Out	Of	IN	Service
-----------------	----------	----------	-----------	-----	----	----	---------

GENERAL	YES	NO	N/A	Note #
Is the building currently occupied?	☒	☐	☐	
Has the occupancy classification and hazard of contents remained the same since the last inspection?	☒	☐	☐	
Are all fire protection systems in service?	☒	☐	☐	
Has the system remained in service without modifications or actuations of devices/alarms since last inspection?	☒	☐	☐	
Fire pump onsite?	☐	☒	☐	

SPRINKLERS (visible)	YES	NO	N/A	Note #
Free of damage or leaks?	☒	☐	☐	
Free of corrosion, foreign material, or paint, loading?	☒	☐	☐	
Installed in proper orientation?	☒	☐	☐	
Fluid in glass bulbs?	☒	☐	☐	
Spare head box contains proper number and type of heads, including wrench(s)?	☒	☐	☐	
Escutcheon plates are present and installed correctly?	☒	☐	☐	
Minimum clearance between sprinklers and storage?	☒	☐	☐	
Sprinklers tested or replaced per appropriate testing schedule?	☒	☐	☐	

Sprinkler heads in use and earliest date on heads:

Standard: _____ Quick Response: _____ ESFR: _____ Dry Pendant: ☒ 2013

PIPING	YES	NO	N/A	Note #
In good condition with no external corrosion?	☒	☐	☐	
No leaks or mechanical damage?	☒	☐	☐	
Correct alignment/No external loads?	☒	☐	☐	
Wet Sprinkler piping not exposed to freezing temperatures?	☒	☐	☐	
Hangers/bracing not damaged or loose?	☒	☐	☐	

FIRE DEPARTMENT CONNECTIONS	YES	NO	N/A	Note #
Visible and accessible?	☒	☐	☐	
Couplings swivel and operate properly?	☒	☐	☐	
Plugs or caps in place?	☒	☐	☐	
Identification signs are in place?	☒	☐	☐	
Ball drip valve is functional/not leaking?	☒	☐	☐	

ANTI-FREEZE SYSTEMS	YES	NO	N/A	Note #
Have all anti-freeze systems been tested?	☐	☐	☒	
Proper signage and placard info in place?	☐	☐	☒	

LOCATION / AREA PROTECTED	TEMP	Note #	LOCATION / AREA PROTECTED	TEMP	Note #
1			3		
2			4		

(*Any additional anti-freeze system results will be listed in Note # Section)

Report to:
Property: WCC, Ceramics Building, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL **Zip:** 60554

Date: 10/13/2021
Job Number:
Technician:

Annual FIRE SPRINKLER INSPECTION REPORT

<i>FIVE YEAR REQUIREMENTS</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
Have all Check Valves, Pre-action or Deluge Valves been internally inspected within the last 5 years?	☒	☐	☐	2018
Has the piping in all systems been checked for obstructive materials within the last 5 years?	☒	☐	☐	2018
System Gauges tested or replaced within the last 5 years?	☒	☐	☐	2018

<i>CONTROL VALVES</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
All Control Valves in the correct (open or closed) position?	☒	☐	☐	
Locked or supervised?	☒	☐	☐	
Easily accessible?	☒	☐	☐	
Free from damage or leaks?	☒	☐	☐	
Proper signage in place?	☒	☐	☐	
Tamper Switches operate properly?	☒	☐	☐	
All Control Valves operated through full range and return to normal position?	☒	☐	☐	
OS&Y Valves properly lubricated?	☒	☐	☐	

<i>Description</i>	<i>Type</i>	<i>Size</i>	<i>Location</i>	<i>Note #</i>
System before backflow	Butterfly	4"	Sprinkler room - SW corner	
System after backflow	Butterfly	4"	Sprinkler room - SW corner	
Sectional for dry	Butterfly	3"	Sprinkler room - SW corner	

(*Any additional control valves will be listed on a separate sheet.)

<i>MAIN DRAIN AND WATERFLOW TEST RESULTS</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
Do main drain test results differ more than 10% from previous test?	☐	☒	☐	

<i>System #</i>	<i>Riser Size</i>	<i>Size of Test Pipe</i>	<i>PSI Static Pressure Before</i>	<i>PSI Residual Pressure</i>	<i>PSI Pressure After</i>	<i>Waterflow Time (sec)</i>	<i>Note #</i>
Dry	3"	1 1/2"	70	60	70	NA	

(*Any additional main drain/waterflow results will be listed on a separate sheet.)

Report to:
Property: WCC, Ceramics Building, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL **Zip:** 60554

Date: 10/13/2021
Job Number:
Technician:

DRY VALVE TRIP TEST REPORT

Dry Pipe Valves		System #		System #		System #		System #	
		Sprinkler room - SW corner							
Manufacturer		Viking							
Valve Model		F-2							
Valve Size		3"							
Valve Serial Number		W605749							
Controlling Sprinklers	(Location)	Thru out							
	(Number)	All							
Date Last Trip Tested or Operated		2020							
Pressure Before Test	Air	25							
	Water	90							
Size and Location of Test Valve		1 1/2"							
Was Valve Below Dry Valve Open Wide at Test?		YES	NO	YES	NO	YES	NO	YES	NO
		☐	☒	☐	☐	☐	☐	☐	☐
(If not, how many turns?)		4							
Tripped at	Air Pressure	6 psi							
	Water Pressure	70							
	Time	15 seconds							
If System Flooded, Time Water Reached Test Opening		NA							
Performance									
Condition of	Interior of Body	Satisfactory							
	Moving Parts	Satisfactory							
	Rubber Facing	Satisfactory							
	Seats	Satisfactory							
		YES	NO	YES	NO	YES	NO	YES	NO
Did Valve Reset?		☒	☐	☐	☐	☐	☐	☐	☐
Did Alarms Operate at Trip Test?		☒	☐	☐	☐	☐	☐	☐	☐
Did Low Air Alarm Operate Properly?		☒	☐	☐	☐	☐	☐	☐	☐
If yes, at:		15 psi							
All Auxiliary Drains Blown Out?		☒	☐	☐	☐	☐	☐	☐	☐
Water Control Valve Left Open?		☒	☐	☐	☐	☐	☐	☐	☐
Alarm Control Valve Left Open?		☒	☐	☐	☐	☐	☐	☐	☐
When Was Last 3-Year Full Flood Trip Test Performed?		NA							

Report to:
Property: WCC, Ceramics Building, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL **Zip:** 60554

Date: 10/13/2021
Job Number:
Technician:

DRY VALVE TRIP TEST REPORT

Quick Opening Devices										
Manufacturer	NA									
Type	NA									
Model	NA									
Device Serial Number	NA									
Air Pressure in Upper Chamber	NA									
Quick Opening Device Tripped at	NA	SEC	NA	LBS	SEC	LBS	SEC	LBS	SEC	LBS
Quick Opening Device Left in Service and Control Valve Left Opened?	YES	NO	YES	NO	YES	NO	YES	NO	YES	NO
	☒	☐	☐	☐	☐	☐	☐	☐	☐	☐

LOW POINT DRAIN LIST								
LOCATION	Drained		Note #	LOCATION	Drained		Note #	
	YES	NO			YES	NO		
ITV	☒	☐			☐	☐		
DPV	☒	☐			☐	☐		
	☐	☐			☐	☐		
	☐	☐			☐	☐		
	☐	☐			☐	☐		
	☐	☐			☐	☐		
	☐	☐			☐	☐		
	☐	☐			☐	☐		
	☐	☐			☐	☐		
	☐	☐			☐	☐		

Note #	THE INSPECTOR SUGGESTS THE FOLLOWING NECESSARY IMPROVEMENTS: (these suggestions are not the result of an engineering survey)

Customer Requirements
* Building Owner is responsible for providing adequate heat (40°F or greater) in all areas where wet-pipe sprinklers are installed. * Building Owner is responsible for draining all low points of water condensation frequently. All low point drains must be in a fully heated area and free of debris. * The dry pipe valve and components must be in a fully heated area at all times. There should be power to the air compressor at all times. Circuit breakers should be checked frequently for blown fuses. Air compressor should be checked for proper oil type and quantity. Air compressor should be on its own dedicated circuit with a locked on switch in the breaker (not a toggle switch on the wall). * An internal pipe examination should be performed every five (5) years. * Accurate Zone Maps are required on all dry systems with all low points clearly marked. * In the event of a low air alarm, immediate action is required.

Customer Acknowledgement _____

 INSPECTOR SIGNATURE	Jason Brut PRINT NAME	149731 NICET #
--	--------------------------	-------------------

Report to:
Property: WCC, Collins Hall, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL Zip: 60554

Date: 10/13/2021
Job Number:
Technician:

Annual FIRE SPRINKLER INSPECTION REPORT

Central Station	Customer takes	POS/Acct	Out	Out	Of	IN	Service
-----------------	----------------	----------	-----	-----	----	----	---------

GENERAL	YES	NO	N/A	Note #
Is the building currently occupied?	☒	☐	☐	
Has the occupancy classification and hazard of contents remained the same since the last inspection?	☒	☐	☐	
Are all fire protection systems in service?	☒	☐	☐	
Has the system remained in service without modifications or actuations of devices/alarms since last inspection?	☒	☐	☐	
Fire pump onsite?	☐	☒	☐	

SPRINKLERS (visible)	YES	NO	N/A	Note #
Free of damage or leaks?	☒	☐	☐	
Free of corrosion, foreign material, or paint, loading?	☒	☐	☐	
Installed in proper orientation?	☒	☐	☐	
Fluid in glass bulbs?	☒	☐	☐	
Spare head box contains proper number and type of heads, including wrench(s)?	☒	☐	☐	
Escutcheon plates are present and installed correctly?	☒	☐	☐	
Minimum clearance between sprinklers and storage?	☒	☐	☐	
Sprinklers tested or replaced per appropriate testing schedule?	☒	☐	☐	

Sprinkler heads in use and earliest date on heads:

Standard: ☒ 2000 Quick Response: _____ ESFR: _____ Dry Pendant: _____

PIPING	YES	NO	N/A	Note #
In good condition with no external corrosion?	☒	☐	☐	
No leaks or mechanical damage?	☒	☐	☐	
Correct alignment/No external loads?	☒	☐	☐	
Wet Sprinkler piping not exposed to freezing temperatures?	☒	☐	☐	
Hangers/bracing not damaged or loose?	☒	☐	☐	

FIRE DEPARTMENT CONNECTIONS	YES	NO	N/A	Note #
Visible and accessible?	☒	☐	☐	
Couplings swivel and operate properly?	☒	☐	☐	
Plugs or caps in place?	☒	☐	☐	
Identification signs are in place?	☒	☐	☐	
Ball drip valve is functional/not leaking?	☒	☐	☐	

ANTI-FREEZE SYSTEMS	YES	NO	N/A	Note #
Have all anti-freeze systems been tested?	☐	☐	☒	
Proper signage and placard info in place?	☐	☐	☒	

LOCATION / AREA PROTECTED	TEMP	Note #	LOCATION / AREA PROTECTED	TEMP	Note #
1			3		
			4		

(*Any additional anti-freeze system results will be listed in Note # Section)

Report to:
Property: WCC, Collins Hall, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL **Zip:** 60554

Date: 10/13/2021
Job Number:
Technician:

Annual FIRE SPRINKLER INSPECTION REPORT

<i>FIVE YEAR REQUIREMENTS</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
Have all Check Valves, Pre-action or Deluge Valves been internally inspected within the last 5 years?	☒	☐	☐	2019
Has the piping in all systems been checked for obstructive materials within the last 5 years?	☒	☐	☐	2019
System Gauges tested or replaced within the last 5 years?	☒	☐	☐	2018

<i>CONTROL VALVES</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
All Control Valves in the correct (open or closed) position?	☒	☐	☐	
Locked or supervised?	☒	☐	☐	
Easily accessible?	☒	☐	☐	
Free from damage or leaks?	☒	☐	☐	
Proper signage in place?	☒	☐	☐	
Tamper Switches operate properly?	☒	☐	☐	
All Control Valves operated through full range and return to normal position?	☒	☐	☐	
OS&Y Valves properly lubricated?	☒	☐	☐	

<i>Description</i>	<i>Type</i>	<i>Size</i>	<i>Location</i>	<i>Note #</i>
System before backflow	OS&Y	4"	NW corner - Storage room	
System after backflow	OS&Y	4"	NW corner - Storage room	

(*Any additional control valves will be listed on a separate sheet.)

<i>MAIN DRAIN AND WATERFLOW TEST RESULTS</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
Do main drain test results differ more than 10% from previous test?	☐	☒	☐	

<i>System #</i>	<i>Riser Size</i>	<i>Size of Test Pipe</i>	<i>PSI Static Pressure Before</i>	<i>PSI Residual Pressure</i>	<i>PSI Pressure After</i>	<i>Waterflow Time (sec)</i>	<i>Note #</i>
Riser	4"	2"	90	50	75	W/60	Manual only

(*Any additional main drain/waterflow results will be listed on a separate sheet.)

Report to:
Property: WCC, Dickson Center, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL Zip: 60554

Date: 10/13/2021
Job Number:
Technician:

Annual FIRE SPRINKLER INSPECTION REPORT

Central Station	Customer takes	POS/Acct	Out	Out	Of	IN	Service
-----------------	----------------	----------	-----	-----	----	----	---------

GENERAL	YES	NO	N/A	Note #
Is the building currently occupied?	☒	☐	☐	
Has the occupancy classification and hazard of contents remained the same since the last inspection?	☒	☐	☐	
Are all fire protection systems in service?	☒	☐	☐	
Has the system remained in service without modifications or actuations of devices/alarms since last inspection?	☒	☐	☐	
Fire pump onsite?	☒	☐	☐	

SPRINKLERS (visible)	YES	NO	N/A	Note #
Free of damage or leaks?	☒	☐	☐	
Free of corrosion, foreign material, or paint, loading?	☒	☐	☐	
Installed in proper orientation?	☒	☐	☐	
Fluid in glass bulbs?	☒	☐	☐	
Spare head box contains proper number and type of heads, including wrench(s)?	☒	☐	☐	
Escutcheon plates are present and installed correctly?	☒	☐	☐	
Minimum clearance between sprinklers and storage?	☒	☐	☐	
Sprinklers tested or replaced per appropriate testing schedule?	☒	☐	☐	

Sprinkler heads in use and earliest date on heads:

Standard: ☒ 2004 Quick Response: _____ ESFR: _____ Dry Pendant: _____

PIPING	YES	NO	N/A	Note #
In good condition with no external corrosion?	☒	☐	☐	
No leaks or mechanical damage?	☒	☐	☐	
Correct alignment/No external loads?	☒	☐	☐	
Wet Sprinkler piping not exposed to freezing temperatures?	☒	☐	☐	
Hangers/bracing not damaged or loose?	☒	☐	☐	

FIRE DEPARTMENT CONNECTIONS	YES	NO	N/A	Note #
Visible and accessible?	☒	☐	☐	
Couplings swivel and operate properly?	☒	☐	☐	
Plugs or caps in place?	☒	☐	☐	
Identification signs are in place?	☒	☐	☐	
Ball drip valve is functional/not leaking?	☒	☐	☐	

ANTI-FREEZE SYSTEMS	YES	NO	N/A	Note #
Have all anti-freeze systems been tested?	☐	☐	☒	
Proper signage and placard info in place?	☐	☐	☒	

LOCATION / AREA PROTECTED	TEMP	Note #	LOCATION / AREA PROTECTED	TEMP	Note #
1			3		
2			4		

(*Any additional anti-freeze system results will be listed in Note # Section)

Date: 10/13/2021
Job Number: 23057300
Technician:
Michael Messacar, Jason Brut, Travis Dunlop

(*Any additional main drain/waterflow results will be listed on a separate sheet.)

Universal Inspection Report

Report # SPI(C) - 149085

General Information

Service Provider:	Allegiant Fire Protection LLC	SP ID:	SP11855
Customer Account #:	--	Address:	2760 Beverly Dr., Suite 9 Aurora Illinois 60503
Phone:	630-506-5535	Fax:	--
General Email:	jthibodeau@allegiantfire.net		
Report Entered By:	Allyse McKinley	User's Email:	amckinley@allegiantfire.net
SP Lead Technician:	Barry Trenholm	Date Inspection Completed:	11/24/2020
Lead Tech Nicet #:	--		
Other License #:	--	Other License Type:	--

Primary AHJ's Name:	Aurora Fire Department	Primary AHJ ID:	ILA11140
AHJ Inspector Name:	--	AHJ Inspector Badge#:	--
Primary AHJ Phone:	630-256-4130	Primary AHJ Email:	FPB@AURORA-IL.ORG
Secondary AHJ's Name:	--	Secondary AHJ ID:	--
Secondary AHJ Phone:	--	Secondary AHJ Email:	--

PO ID:	--		
Business Occupant:	WAUBONSEE COMMUNITY COLLEGE		
Region:	No Region	Location:	18 - S - River St
Number :	18	Street Prefix :	S
Street Name :	River St	Unit # :	--
City:	Aurora	State:	Illinois
Zip:	60506	Phone:	630-466-7900
Contact Name:	Edward Plante		
Contact Phone:	630-466-7900	Contact Email :	eplante@waubonsee.edu
PIN#:	--	Classification:	--

Alternate PO Details			
Alternate PO ID:	--	Contact Name:	--
Contact Phone:	--	Contact Email :	--

Attach Report

Report:	SPI - Sprinkler System Inspection
Frequency:	Annual
Attachment:	There is a supplemental file for this report that is not available in PDF view. Please visit inspectionreportsonline.net to access that file.
Next Inspection Due Date:	December - 2021
Report Completed By:	--
Email Sent To:	eplante@waubonsee.edu

Notes

Entered By	Notes Type	Date	Note
Allyse McKinley	New Deficiency	12/04/2020	5 year internal inspection and FDC hydro due
IROL Review	AHJ	12/08/2020	Deficiencies noted, email sent to PM
IROL Review	AHJ	01/01/2021	Reminder email sent to PM

Test performed in accordance with the following code or standard:

Report to:
Property: WCC, Erickson Hall, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL **Zip:** 60554

Date: 10/13/2021
Job Number:
Technician:

Annual FIRE SPRINKLER INSPECTION REPORT

Central Station	Customer takes	POS/Acct	Out	Out	Of	IN	Service
-----------------	----------------	----------	-----	-----	----	----	---------

GENERAL	YES	NO	N/A	Note #
Is the building currently occupied?	☒	☐	☐	
Has the occupancy classification and hazard of contents remained the same since the last inspection?	☒	☐	☐	
Are all fire protection systems in service?	☒	☐	☐	
Has the system remained in service without modifications or actuations of devices/alarms since last inspection?	☒	☐	☐	
Fire pump onsite?	☐	☒	☐	

SPRINKLERS (visible)	YES	NO	N/A	Note #
Free of damage or leaks?	☒	☐	☐	
Free of corrosion, foreign material, or paint, loading?	☒	☐	☐	
Installed in proper orientation?	☒	☐	☐	
Fluid in glass bulbs?	☒	☐	☐	
Spare head box contains proper number and type of heads, including wrench(s)?	☒	☐	☐	
Escutcheon plates are present and installed correctly?	☒	☐	☐	
Minimum clearance between sprinklers and storage?	☒	☐	☐	
Sprinklers tested or replaced per appropriate testing schedule?	☒	☐	☐	

Sprinkler heads in use and earliest date on heads:

Standard: ☒ **2014** Quick Response: _____ ESFR: _____ Dry Pendant: _____

PIPING	YES	NO	N/A	Note #
In good condition with no external corrosion?	☒	☐	☐	
No leaks or mechanical damage?	☒	☐	☐	
Correct alignment/No external loads?	☒	☐	☐	
Wet Sprinkler piping not exposed to freezing temperatures?	☒	☐	☐	
Hangers/bracing not damaged or loose?	☒	☐	☐	

FIRE DEPARTMENT CONNECTIONS	YES	NO	N/A	Note #
Visible and accessible?	☒	☐	☐	
Couplings swivel and operate properly?	☒	☐	☐	
Plugs or caps in place?	☒	☐	☐	
Identification signs are in place?	☒	☐	☐	
Ball drip valve is functional/not leaking?	☒	☐	☐	

ANTI-FREEZE SYSTEMS	YES	NO	N/A	Note #
Have all anti-freeze systems been tested?	☐	☐	☒	
Proper signage and placard info in place?	☐	☐	☒	

LOCATION / AREA PROTECTED	TEMP	Note #	LOCATION / AREA PROTECTED	TEMP	Note #
1			3		
2			4		

(*Any additional anti-freeze system results will be listed in Note # Section)

Report to:
Property: WCC, Erickson Hall, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL **Zip:** 60554

Date: 10/13/2021
Job Number:
Technician:

Annual FIRE SPRINKLER INSPECTION REPORT

<i>FIVE YEAR REQUIREMENTS</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
Have all Check Valves, Pre-action or Deluge Valves been internally inspected within the last 5 years?	☒	☐	☐	2019
Has the piping in all systems been checked for obstructive materials within the last 5 years?	☒	☐	☐	2019
System Gauges tested or replaced within the last 5 years?	☒	☐	☐	2018

<i>CONTROL VALVES</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
All Control Valves in the correct (open or closed) position?	☒	☐	☐	
Locked or supervised?	☒	☐	☐	
Easily accessible?	☒	☐	☐	
Free from damage or leaks?	☒	☐	☐	
Proper signage in place?	☒	☐	☐	
Tamper Switches operate properly?	☒	☐	☐	
All Control Valves operated through full range and return to normal position?	☒	☐	☐	
OS&Y Valves properly lubricated?	☒	☐	☐	

<i>Description</i>	<i>Type</i>	<i>Size</i>	<i>Location</i>	<i>Note #</i>
Before Backflow	Butterfly	3"	Mech room ERK-13	
After Backflow	Butterfly	3"	Mech room ERK-13	
Riser 1	Butterfly	3"	Mech room ERK-13	
Riser 2	Butterfly	3"	Mech room ERK-13	
Riser 3	Butterfly	3"	Mech room ERK-13	
Riser 4	Butterfly	3"	Mech room ERK-13	

(*Any additional control valves will be listed on a separate sheet.)

<i>MAIN DRAIN AND WATERFLOW TEST RESULTS</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
Do main drain test results differ more than 10% from previous test?	☐	☐	☐	

<i>System #</i>	<i>Riser Size</i>	<i>Size of Test Pipe</i>	<i>PSI Static Pressure Before</i>	<i>PSI Residual Pressure</i>	<i>PSI Pressure After</i>	<i>Waterflow Time (sec)</i>	<i>Note #</i>
Riser 1	3"	2"	110	75	80	W/60	
Riser 2	3"	2"	110	75	80	W/60	
Riser 3	3"	2"	110	75	80	W/60	
Riser 4	3"	2"	110	75	80	W/60	

(*Any additional main drain/waterflow results will be listed on a separate sheet.)



2760 Beverly Dr.
Suite 9
Aurora, IL 60502
630.506.5535
www.allegiantfire.net

Report to: U.S. Fire & Safety Equipment Company
Property: WCC, Erickson Hall, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL **Zip:** 60554

Date: 10/13/2021
Job Number: 23057301
Technician: Michael Messacar, Jason Brut

Annual FIRE SPRINKLER INSPECTION REPORT

Central Station	Customer takes	POS/Acct	Out	Out	Of	IN	Service
-----------------	----------------	----------	-----	-----	----	----	---------

GENERAL	YES	NO	N/A	Note #
Is the building currently occupied?	☒	☐	☐	
Has the occupancy classification and hazard of contents remained the same since the last inspection?	☒	☐	☐	
Are all fire protection systems in service?	☒	☐	☐	
Has the system remained in service without modifications or actuations of devices/alarms since last inspection?	☒	☐	☐	
Fire pump onsite?	☐	☒	☐	

SPRINKLERS (visible)	YES	NO	N/A	Note #
Free of damage or leaks?	☒	☐	☐	
Free of corrosion, foreign material, or paint, loading?	☒	☐	☐	
Installed in proper orientation?	☒	☐	☐	
Fluid in glass bulbs?	☒	☐	☐	
Spare head box contains proper number and type of heads, including wrench(s)?	☒	☐	☐	
Escutcheon plates are present and installed correctly?	☒	☐	☐	
Minimum clearance between sprinklers and storage?	☒	☐	☐	
Sprinklers tested or replaced per appropriate testing schedule?	☒	☐	☐	

Sprinkler heads in use and earliest date on heads:

Standard: ☒ 2014 Quick Response: _____ ESFR: _____ Dry Pendant: _____

PIPING	YES	NO	N/A	Note #
In good condition with no external corrosion?	☒	☐	☐	
No leaks or mechanical damage?	☒	☐	☐	
Correct alignment/No external loads?	☒	☐	☐	
Wet Sprinkler piping not exposed to freezing temperatures?	☒	☐	☐	
Hangers/bracing not damaged or loose?	☒	☐	☐	

FIRE DEPARTMENT CONNECTIONS	YES	NO	N/A	Note #
Visible and accessible?	☒	☐	☐	
Couplings swivel and operate properly?	☒	☐	☐	
Plugs or caps in place?	☒	☐	☐	
Identification signs are in place?	☒	☐	☐	
Ball drip valve is functional/not leaking?	☒	☐	☐	

ANTI-FREEZE SYSTEMS	YES	NO	N/A	Note #
Have all anti-freeze systems been tested?	☐	☐	☒	
Proper signage and placard info in place?	☐	☐	☒	

LOCATION / AREA PROTECTED	TEMP	Note #	LOCATION / AREA PROTECTED	TEMP	Note #
1			3		
2			4		

(*Any additional anti-freeze system results will be listed in Note # Section)



2760 Beverly Dr.
Suite 9
Aurora, IL 60502
630.506.5535
www.allegiantfire.net

Report to: U.S. Fire & Safety Equipment Company
Property: WCC, Erickson Hall, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL **Zip:** 60554

Date: 10/13/2021
Job Number: 23057301
Technician: Michael Messacar, Jason Brut

Annual FIRE SPRINKLER INSPECTION REPORT

<i>FIVE YEAR REQUIREMENTS</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
Have all Check Valves, Pre-action or Deluge Valves been internally inspected within the last 5 years?	☒	☐	☐	2019
Has the piping in all systems been checked for obstructive materials within the last 5 years?	☒	☐	☐	2019
System Gauges tested or replaced within the last 5 years?	☒	☐	☐	2018

<i>CONTROL VALVES</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
All Control Valves in the correct (open or closed) position?	☒	☐	☐	
Locked or supervised?	☒	☐	☐	
Easily accessible?	☒	☐	☐	
Free from damage or leaks?	☒	☐	☐	
Proper signage in place?	☒	☐	☐	
Tamper Switches operate properly?	☒	☐	☐	
All Control Valves operated through full range and return to normal position?	☒	☐	☐	
OS&Y Valves properly lubricated?	☒	☐	☐	

<i>Description</i>	<i>Type</i>	<i>Size</i>	<i>Location</i>	<i>Note #</i>
Before Backflow	Butterfly	3"	Mech room ERK-13	
After Backflow	Butterfly	3"	Mech room ERK-13	
Riser 1	Butterfly	3"	Mech room ERK-13	
Riser 2	Butterfly	3"	Mech room ERK-13	
Riser 3	Butterfly	3"	Mech room ERK-13	
Riser 4	Butterfly	3"	Mech room ERK-13	

(*Any additional control valves will be listed on a separate sheet.)

<i>MAIN DRAIN AND WATERFLOW TEST RESULTS</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
Do main drain test results differ more than 10% from previous test?	☐	☐	☐	

<i>System #</i>	<i>Riser Size</i>	<i>Size of Test Pipe</i>	<i>PSI Static Pressure Before</i>	<i>PSI Residual Pressure</i>	<i>PSI Pressure After</i>	<i>Waterflow Time (sec)</i>	<i>Note #</i>
Riser 1	3"	2"	110	75	80	W/60	
Riser 2	3"	2"	110	75	80	W/60	
Riser 3	3"	2"	110	75	80	W/60	
Riser 4	3"	2"	110	75	80	W/60	

(*Any additional main drain/waterflow results will be listed on a separate sheet.)



2760 Beverly Dr.
Suite 9
Aurora, IL 60502
630.506.5535
www.allegiantfire.net

Report to: U.S. Fire & Safety Equipment Company
Property: WCC, Erickson Hall, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL **Zip:** 60554

Date: 10/13/2021
Job Number: 23057301
Technician: Michael Messacar, Jason Brut

Annual FIRE SPRINKLER INSPECTION REPORT

*THE INSPECTOR SUGGESTS THE FOLLOWING NECESSARY IMPROVEMENTS:
(these suggestions are not the result of an engineering survey)*

Note #

MODIFICATIONS OR CORRECTIONS MADE DURING THIS INSPECTION:

INSPECTION & SUGGESTED IMPROVEMENTS WERE DISCUSSED WITH THE UNDERSIGNED OWNER OR OWNERS REPRESENTATIVE:

By this signature, I certify: I state that the information on this form is correct at the time and place of my inspection, and that all equipment tested now was left in operational condition upon completion of this inspection except as noted in comments above.

Verbal checkout with Laura

OWNER / REPRESENTATIVE SIGNATURE

Verbal checkout with Laura

PRINT NAME

10/13/2021

DATE

INSPECTOR SIGNATURE

Michael Messacar, Jason Brut

PRINT NAME

149731

NICET #

Sprinkler Inspection

Report # SPI(C) - 188504

General Information

Service Provider:	Allegiant Fire Protection LLC	SP ID:	SP11855
Customer Account #:	--	Address:	2760 Beverly Dr., Suite 9 Aurora Illinois 60503
Phone:	630-506-5535	Fax:	--
General Email:	jthibodeau@allegiantfire.net		
Report Entered By:	Kaitlin Moore	User's Email:	kmoore@allegiantfire.net
SP Lead Technician:	Jason Brut	Date Inspection Completed:	10/13/2021
Lead Tech Nicet #:	149731		
Other License #:	--	Other License Type:	--

Primary AHJ's Name:	Sugar Grove Fire Protection District	Primary AHJ ID:	ILA11126
AHJ Inspector Name:	--	AHJ Inspector Badge#:	--
Primary AHJ Phone:	630-466-4513	Primary AHJ Email:	wparson@sugargrovecfire.com
Secondary AHJ's Name:	--	Secondary AHJ ID:	--
Secondary AHJ Phone:	--	Secondary AHJ Email:	--

PO ID:	--		
Business Occupant:	WAUBONSEE COMMUNITY COLLEGE		
Region:	No Region	Location:	4S783 - State Route 47 - #Erickson Hall
Number :	4S783	Street Prefix :	--
Street Name :	State Route 47	Unit # :	Erickson Hall
City:	Sugar Grove	State:	Illinois
Zip:	60554	Phone:	630-466-7900
Contact Name:	Edward Plante		
Contact Phone:	630-466-7900	Contact Email :	eplante@waubonsee.edu
PIN#:	--	Classification:	--

Alternate PO Details			
Alternate PO ID:	--	Contact Name:	--
Contact Phone:	--	Contact Email :	--

Attach Report

Report:	SPI - Sprinkler System Inspection
Frequency:	Annual
Attachment:	There is a supplemental file for this report that is not available in PDF view. Please visit inspectionreportsonline.net to access that file.
Next Inspection Due Date:	October - 2022
Report Completed By:	--
Email Sent To:	eplante@waubonsee.edu

Notes

Entered By	Notes Type	Date	Note

Test performed in accordance with the following code or standard:

Report to:**Property:** WCC, Fox Valley, 2060 Ogden Ave**Address:** 2060 Ogden Avenue**City:** Aurora**State:** IL **Zip:** 60504**Date:****Job Number:****Technician:**

Annual FIRE SPRINKLER INSPECTION REPORT

Central Station	POS/Acct	Handled by customer	Out	IN
-----------------	----------	---------------------	-----	----

GENERAL	YES	NO	N/A	Note #
Is the building currently occupied?	☒	☐	☐	
Has the occupancy classification and hazard of contents remained the same since the last inspection?	☒	☐	☐	
Are all fire protection systems in service?	☒	☐	☐	
Has the system remained in service without modifications or actuations of devices/alarms since last inspection?	☒	☐	☐	
Fire pump onsite?	☐	☒	☐	

SPRINKLERS (visible)	YES	NO	N/A	Note #
Free of damage or leaks?	☒	☐	☐	
Free of corrosion, foreign material, or paint, loading?	☒	☐	☐	
Installed in proper orientation?	☒	☐	☐	
Fluid in glass bulbs?	☒	☐	☐	
Spare head box contains proper number and type of heads, including wrench(s)?	☒	☐	☐	
Escutcheon plates are present and installed correctly?	☒	☐	☐	
Minimum clearance between sprinklers and storage?	☒	☐	☐	
Sprinklers tested or replaced per appropriate testing schedule?	☒	☐	☐	

Sprinkler heads in use and earliest date on heads:

Standard: ☒ 2009 Quick Response: _____ ESFR: _____ Dry Pendant: _____

PIPING	YES	NO	N/A	Note #
In good condition with no external corrosion?	☒	☐	☐	
No leaks or mechanical damage?	☒	☐	☐	
Correct alignment/No external loads?	☒	☐	☐	
Wet Sprinkler piping not exposed to freezing temperatures?	☒	☐	☐	
Hangers/bracing not damaged or loose?	☒	☐	☐	

FIRE DEPARTMENT CONNECTIONS	YES	NO	N/A	Note #
Visible and accessible?	☒	☐	☐	
Couplings swivel and operate properly?	☒	☐	☐	
Plugs or caps in place?	☒	☐	☐	
Identification signs are in place?	☒	☐	☐	
Ball drip valve is functional/not leaking?	☒	☐	☐	

ANTI-FREEZE SYSTEMS	YES	NO	N/A	Note #
Have all anti-freeze systems been tested?	☐	☐	☒	
Proper signage and placard info in place?	☐	☐	☒	

LOCATION / AREA PROTECTED	TEMP	Note #	LOCATION / AREA PROTECTED	TEMP	Note #
1			3		
2			4		

(*Any additional anti-freeze system results will be listed in Note # Section)

Report to:**Property:** WCC, Fox Valley, 2060 Ogden Ave**Address:** 2060 Ogden Avenue**City:** Aurora**State:** IL **Zip:** 60504**Date:****Job Number:****Technician:****Annual FIRE SPRINKLER INSPECTION REPORT**

FIVE YEAR REQUIREMENTS	YES	NO	N/A	Note #
Have all Check Valves, Pre-action or Deluge Valves been internally inspected within the last 5 years?	☐	☒	☐	
Has the piping in all systems been checked for obstructive materials within the last 5 years?	☐	☒	☐	
System Gauges tested or replaced within the last 5 years?	☒	☐	☐	2019

CONTROL VALVES	YES	NO	N/A	Note #
All Control Valves in the correct (open or closed) position?	☒	☐	☐	
Locked or supervised?	☒	☐	☐	
Easily accessible?	☒	☐	☐	
Free from damage or leaks?	☒	☐	☐	
Proper signage in place?	☒	☐	☐	
Tamper Switches operate properly?	☒	☐	☐	
All Control Valves operated through full range and return to normal position?	☒	☐	☐	
OS&Y Valves properly lubricated?	☒	☐	☐	

Description	Type	Size	Location	Note #
City 1	OS&Y	8"	Sprinkler room	
City 2	OS&Y	8"	Sprinkler room	
Basement	Butterfly	2"	Sprinkler room	
1st floor	Butterfly	3"	Staff workroom off stair 2	
2nd floor	Butterfly	3"	2nd floor stairs	

(*Any additional control valves will be listed on a separate sheet.)

MAIN DRAIN AND WATERFLOW TEST RESULTS	YES	NO	N/A	Note #
Do main drain test results differ more than 10% from previous test?	☐	☒	☐	

System #	Riser Size	Size of Test Pipe	PSI Static Pressure Before	PSI Residual Pressure	PSI Pressure After	Waterflow Time (sec)	Note #
Main riser	4"	2"	65	45	55	W/60	
1st floor	3"	>	65	45	55	W/60	
2nd floor	3"	1"	65	45	55	W/60	
Basement	2"	1"	65	45	55	W/60	

(*Any additional main drain/waterflow results will be listed on a separate sheet.)

Report to:
Property: WCC, Henning Hall, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL **Zip:** 60554

Date: 10/16/2021
Job Number:
Technician:

Annual FIRE SPRINKLER INSPECTION REPORT

Central Station	POS/Acct	Handled by customer	Out	IN
-----------------	----------	---------------------	-----	----

GENERAL	YES	NO	N/A	Note #
Is the building currently occupied?	☒	☐	☐	
Has the occupancy classification and hazard of contents remained the same since the last inspection?	☒	☐	☐	
Are all fire protection systems in service?	☒	☐	☐	
Has the system remained in service without modifications or actuations of devices/alarms since last inspection?	☒	☐	☐	
Fire pump onsite?	☒	☐	☐	

SPRINKLERS (visible)	YES	NO	N/A	Note #
Free of damage or leaks?	☒	☐	☐	
Free of corrosion, foreign material, or paint, loading?	☒	☐	☐	
Installed in proper orientation?	☒	☐	☐	
Fluid in glass bulbs?	☒	☐	☐	
Spare head box contains proper number and type of heads, including wrench(s)?	☒	☐	☐	
Escutcheon plates are present and installed correctly?	☒	☐	☐	
Minimum clearance between sprinklers and storage?	☒	☐	☐	
Sprinklers tested or replaced per appropriate testing schedule?	☒	☐	☐	

Sprinkler heads in use and earliest date on heads:

Standard: ☒ 1992 Quick Response: _____ ESFR: _____ Dry Pendant: _____

PIPING	YES	NO	N/A	Note #
In good condition with no external corrosion?	☒	☐	☐	
No leaks or mechanical damage?	☒	☐	☐	
Correct alignment/No external loads?	☒	☐	☐	
Wet Sprinkler piping not exposed to freezing temperatures?	☒	☐	☐	
Hangers/bracing not damaged or loose?	☒	☐	☐	

FIRE DEPARTMENT CONNECTIONS	YES	NO	N/A	Note #
Visible and accessible?	☒	☐	☐	
Couplings swivel and operate properly?	☒	☐	☐	
Plugs or caps in place?	☒	☐	☐	
Identification signs are in place?	☒	☐	☐	
Ball drip valve is functional/not leaking?	☒	☐	☐	

ANTI-FREEZE SYSTEMS	YES	NO	N/A	Note #
Have all anti-freeze systems been tested?	☐	☐	☒	
Proper signage and placard info in place?	☐	☐	☒	

LOCATION / AREA PROTECTED	TEMP	Note #	LOCATION / AREA PROTECTED	TEMP	Note #
1			3		
2			4		

(*Any additional anti-freeze system results will be listed in Note # Section)

Report to:
Property: WCC, Henning Hall, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL **Zip:** 60554

Date: 10/16/2021
Job Number:
Technician:

Annual FIRE SPRINKLER INSPECTION REPORT

<i>FIVE YEAR REQUIREMENTS</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
Have all Check Valves, Pre-action or Deluge Valves been internally inspected within the last 5 years?	☐	☒	☐	1
Has the piping in all systems been checked for obstructive materials within the last 5 years?	☐	☒	☐	1
System Gauges tested or replaced within the last 5 years?	☒	☐	☐	2018

<i>CONTROL VALVES</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
All Control Valves in the correct (open or closed) position?	☒	☐	☐	
Locked or supervised?	☒	☐	☐	
Easily accessible?	☒	☐	☐	
Free from damage or leaks?	☒	☐	☐	
Proper signage in place?	☒	☐	☐	
Tamper Switches operate properly?	☒	☐	☐	
All Control Valves operated through full range and return to normal position?	☒	☐	☐	
OS&Y Valves properly lubricated?	☒	☐	☐	

<i>Description</i>	<i>Type</i>	<i>Size</i>	<i>Location</i>	<i>Note #</i>
System before backflow	OS&Y	3"	Lower level mech room - SE corner	
System after backflow	OS&Y	3"	Lower level mech room - SE corner	

(*Any additional control valves will be listed on a separate sheet.)

<i>MAIN DRAIN AND WATERFLOW TEST RESULTS</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
Do main drain test results differ more than 10% from previous test?	☐	☒	☐	

<i>System #</i>	<i>Riser Size</i>	<i>Size of Test Pipe</i>	<i>PSI Static Pressure Before</i>	<i>PSI Residual Pressure</i>	<i>PSI Pressure After</i>	<i>Waterflow Time (sec)</i>	<i>Note #</i>
Riser	3"	1 1/4"	115	65	75	W/60	

(*Any additional main drain/waterflow results will be listed on a separate sheet.)

MYERS Battery Backup Inverters:

Field House

S/N: 87534L1-1 P/N: CM3-90-277-277 (08) BAT-CG12033

Rm 164

S/N: 87534L2-2 P/N: CM4-90-277-277 (16) BAT-CG12033

Rm 193 EMC

S/N: 87534L3-1 P/N: CM2-90-277-277 (12) BAT-CG12033

Rm 193 EMB

S/N: 87534L2-3 P/N: CM4-90-277-277 (16) BAT-CG12033

Rm 153 EMD

Erickson Hall

S/N: 87534L2-1 P/N: CM4-90-277-277 (16) BAT-CG12033

Boiler Rm

S/N: 87534L4-1 P/N: CM2-90-277-277 (08) BAT-CG12033

Rm 210 EMG2

S/N: 87534L4-2 P/N: CM2-90-277-277 (08) BAT-CG12033

Rm 210 EMG1

Scope: Perform Annual Preventative Maintenance for the (7) Myers systems listed below.

Including the following:

- 1)Perform an individual Alber/ Midtronics test on each battery.
- 2)Record date of battery test and correlate numbering process within battery cabinets
- 3)Retorque all connections in battery cabinets. Record and clean all corrosion problems.
- 4)Provide a report (soft file) of results

Quote: CM Series Annual Maintenance service: \$ _____

Quote: CM series EM Lighting Inverter12v Battery: \$ _____

Quote: CM Series Capacitor replacement: \$ _____

Report to:
Property: WCC, Ops Building, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL **Zip:** 60554

Date: 10/13/2021
Job Number:
Technician:

Annual FIRE SPRINKLER INSPECTION REPORT

Central Station	Customer took	POS/Acct	Out	Out	Of	IN	Service
-----------------	---------------	----------	-----	-----	----	----	---------

GENERAL	YES	NO	N/A	Note #
Is the building currently occupied?	☒	☐	☐	
Has the occupancy classification and hazard of contents remained the same since the last inspection?	☒	☐	☐	
Are all fire protection systems in service?	☒	☐	☐	
Has the system remained in service without modifications or actuations of devices/alarms since last inspection?	☒	☐	☐	
Fire pump onsite?	☒	☐	☐	

SPRINKLERS (visible)	YES	NO	N/A	Note #
Free of damage or leaks?	☒	☐	☐	
Free of corrosion, foreign material, or paint, loading?	☒	☐	☐	
Installed in proper orientation?	☒	☐	☐	
Fluid in glass bulbs?	☒	☐	☐	
Spare head box contains proper number and type of heads, including wrench(s)?	☒	☐	☐	
Escutcheon plates are present and installed correctly?	☒	☐	☐	
Minimum clearance between sprinklers and storage?	☒	☐	☐	
Sprinklers tested or replaced per appropriate testing schedule?	☒	☐	☐	

Sprinkler heads in use and earliest date on heads:

Standard: ☒ 2005 Quick Response: _____ ESFR: _____ Dry Pendant: _____

PIPING	YES	NO	N/A	Note #
In good condition with no external corrosion?	☒	☐	☐	
No leaks or mechanical damage?	☒	☐	☐	
Correct alignment/No external loads?	☒	☐	☐	
Wet Sprinkler piping not exposed to freezing temperatures?	☒	☐	☐	
Hangers/bracing not damaged or loose?	☒	☐	☐	

FIRE DEPARTMENT CONNECTIONS	YES	NO	N/A	Note #
Visible and accessible?	☒	☐	☐	
Couplings swivel and operate properly?	☒	☐	☐	
Plugs or caps in place?	☒	☐	☐	
Identification signs are in place?	☒	☐	☐	
Ball drip valve is functional/not leaking?	☒	☐	☐	

ANTI-FREEZE SYSTEMS	YES	NO	N/A	Note #
Have all anti-freeze systems been tested?	☐	☐	☒	
Proper signage and placard info in place?	☐	☐	☒	

LOCATION / AREA PROTECTED	TEMP	Note #	LOCATION / AREA PROTECTED	TEMP	Note #
1			3		
2			4		

(*Any additional anti-freeze system results will be listed in Note # Section)

Report to:
Property: WCC, Ops Building, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL **Zip:** 60554

Date: 10/13/2021
Job Number:
Technician:

Annual FIRE SPRINKLER INSPECTION REPORT

<i>FIVE YEAR REQUIREMENTS</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
Have all Check Valves, Pre-action or Deluge Valves been internally inspected within the last 5 years?	☐	☒	☐	NA
Has the piping in all systems been checked for obstructive materials within the last 5 years?	☐	☒	☐	NA
System Gauges tested or replaced within the last 5 years?	☒	☐	☐	2018

<i>CONTROL VALVES</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
All Control Valves in the correct (open or closed) position?	☒	☐	☐	
Locked or supervised?	☒	☐	☐	
Easily accessible?	☒	☐	☐	
Free from damage or leaks?	☒	☐	☐	
Proper signage in place?	☒	☐	☐	
Tamper Switches operate properly?	☒	☐	☐	
All Control Valves operated through full range and return to normal position?	☒	☐	☐	
OS&Y Valves properly lubricated?	☒	☐	☐	

<i>Description</i>	<i>Type</i>	<i>Size</i>	<i>Location</i>	<i>Note #</i>
System before backflow	OS&Y	6"	West whse	
System after backflow	OS&Y	6"	West whse	

(*Any additional control valves will be listed on a separate sheet.)

<i>MAIN DRAIN AND WATERFLOW TEST RESULTS</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
Do main drain test results differ more than 10% from previous test?	☐	☒	☐	

<i>System #</i>	<i>Riser Size</i>	<i>Size of Test Pipe</i>	<i>PSI Static Pressure Before</i>	<i>PSI Residual Pressure</i>	<i>PSI Pressure After</i>	<i>Waterflow Time (sec)</i>	<i>Note #</i>
Riser	4"	2"	90	60	75	W/60	Manual only

(*Any additional main drain/waterflow results will be listed on a separate sheet.)



2760 Beverly Dr.
Suite 9
Aurora, IL 60502
630.506.5535
www.allegiantfire.net

Report to: U.S. Fire & Safety Equipment Company
Property: WCC, Ops Building, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL **Zip:** 60554

Date: 10/13/2021
Job Number: 23057304
Technician: Michael Messacar, Jason Brut

Annual FIRE SPRINKLER INSPECTION REPORT

Central Station	Customer took	POS/Acct	Out	Out	Of	IN	Service
-----------------	---------------	----------	-----	-----	----	----	---------

GENERAL	YES	NO	N/A	Note #
Is the building currently occupied?	☒	☐	☐	
Has the occupancy classification and hazard of contents remained the same since the last inspection?	☒	☐	☐	
Are all fire protection systems in service?	☒	☐	☐	
Has the system remained in service without modifications or actuations of devices/alarms since last inspection?	☒	☐	☐	
Fire pump onsite?	☒	☐	☐	

SPRINKLERS (visible)	YES	NO	N/A	Note #
Free of damage or leaks?	☒	☐	☐	
Free of corrosion, foreign material, or paint, loading?	☒	☐	☐	
Installed in proper orientation?	☒	☐	☐	
Fluid in glass bulbs?	☒	☐	☐	
Spare head box contains proper number and type of heads, including wrench(s)?	☒	☐	☐	
Escutcheon plates are present and installed correctly?	☒	☐	☐	
Minimum clearance between sprinklers and storage?	☒	☐	☐	
Sprinklers tested or replaced per appropriate testing schedule?	☒	☐	☐	

Sprinkler heads in use and earliest date on heads:

Standard: ☒ 2005 Quick Response: _____ ESFR: _____ Dry Pendant: _____

PIPING	YES	NO	N/A	Note #
In good condition with no external corrosion?	☒	☐	☐	
No leaks or mechanical damage?	☒	☐	☐	
Correct alignment/No external loads?	☒	☐	☐	
Wet Sprinkler piping not exposed to freezing temperatures?	☒	☐	☐	
Hangers/bracing not damaged or loose?	☒	☐	☐	

FIRE DEPARTMENT CONNECTIONS	YES	NO	N/A	Note #
Visible and accessible?	☒	☐	☐	
Couplings swivel and operate properly?	☒	☐	☐	
Plugs or caps in place?	☒	☐	☐	
Identification signs are in place?	☒	☐	☐	
Ball drip valve is functional/not leaking?	☒	☐	☐	

ANTI-FREEZE SYSTEMS	YES	NO	N/A	Note #
Have all anti-freeze systems been tested?	☐	☐	☒	
Proper signage and placard info in place?	☐	☐	☒	

LOCATION / AREA PROTECTED	TEMP	Note #	LOCATION / AREA PROTECTED	TEMP	Note #
1			3		
2			4		

(*Any additional anti-freeze system results will be listed in Note # Section)

Date: 10/13/2021
Job Number: 23057304
Technician:
Michael Messacar, Jason Brut

FIVE YEAR REQUIREMENTS

CONTROL VALVES

Description

(*Any additional control valves will be listed on a separate sheet.)

MAIN DRAIN AND WATERFLOW TEST RESULTS

System #

(*Any additional main drain/waterflow results will be listed on a separate sheet.)



2760 Beverly Dr.
Suite 9
Aurora, IL 60502
630.506.5535
www.allegiantfire.net

Report to: U.S. Fire & Safety Equipment Company
Property: WCC, Ops Building, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL **Zip:** 60554

Date: 10/13/2021
Job Number: 23057304
Technician: Michael Messacar, Jason Brut

Annual FIRE SPRINKLER INSPECTION REPORT

*THE INSPECTOR SUGGESTS THE FOLLOWING NECESSARY IMPROVEMENTS:
(these suggestions are not the result of an engineering survey)*

Note #

#1 System due for 5 year internal inspection and FDC hydro.

Note: ITV was left open for 90 seconds and water flow device did not trip. Manual test yield and alarm within 65 seconds. Possible issue in water pressure

MODIFICATIONS OR CORRECTIONS MADE DURING THIS INSPECTION:

INSPECTION & SUGGESTED IMPROVEMENTS WERE DISCUSSED WITH THE UNDERSIGNED OWNER OR OWNERS REPRESENTATIVE:

By this signature, I certify: I state that the information on this form is correct at the time and place of my inspection, and that all equipment tested now was left in operational condition upon completion of this inspection except as noted in comments above.

Verbal checkout with Laura

OWNER / REPRESENTATIVE SIGNATURE

Verbal checkout with Laura

PRINT NAME

10/13/2021

DATE

INSPECTOR SIGNATURE

Michael Messacar, Jason Brut

PRINT NAME

149731

NICET #

Sprinkler Inspection

Report # SPI(C) - 188502

General Information

Service Provider:	Allegiant Fire Protection LLC	SP ID:	SP11855
Customer Account #:	--	Address:	2760 Beverly Dr., Suite 9 Aurora Illinois 60503
Phone:	630-506-5535	Fax:	--
General Email:	jthibodeau@allegiantfire.net		
Report Entered By:	Kaitlin Moore	User's Email:	kmoore@allegiantfire.net
SP Lead Technician:	Jason Brut	Date Inspection Completed:	10/13/2021
Lead Tech Nicet #:	149731		
Other License #:	--	Other License Type:	--

Primary AHJ's Name:	Sugar Grove Fire Protection District	Primary AHJ ID:	ILA11126
AHJ Inspector Name:	--	AHJ Inspector Badge#:	--
Primary AHJ Phone:	630-466-4513	Primary AHJ Email:	wparson@sugargrovecfire.com
Secondary AHJ's Name:	--	Secondary AHJ ID:	--
Secondary AHJ Phone:	--	Secondary AHJ Email:	--

PO ID:	--		
Business Occupant:	WAUBONSEE COMMUNITY COLLEGE		
Region:	No Region	Location:	4S783 - State Route 47 - #Ops Building
Number :	4S783	Street Prefix :	--
Street Name :	State Route 47	Unit # :	Ops Building
City:	Sugar Grove	State:	Illinois
Zip:	60554	Phone:	630-466-7900
Contact Name:	EDWARD PLANTE		
Contact Phone:	630-466-7900	Contact Email :	eplante@waubonsee.edu
PIN#:	--	Classification:	--

Alternate PO Details			
Alternate PO ID:	--	Contact Name:	--
Contact Phone:	--	Contact Email :	--

Attach Report

Report:	SPI - Sprinkler System Inspection
Frequency:	Annual
Attachment:	There is a supplemental file for this report that is not available in PDF view. Please visit inspectionreportsonline.net to access that file.
Next Inspection Due Date:	October - 2022
Report Completed By:	--
Email Sent To:	eplante@waubonsee.edu

Notes

Entered By	Notes Type	Date	Note
Kaitlin Moore	New Deficiency	10/15/2021	System due for 5 year internal inspection and FDC hydro.

Test performed in accordance with the following code or standard:

Report to:
Property: WCC, Science Building, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL **Zip:** 60554

Date: 10/16/2021
Job Number:
Technician:

Annual FIRE SPRINKLER INSPECTION REPORT

Central Station	POS/Acct	Out	IN
-----------------	----------	-----	----

GENERAL	YES	NO	N/A	Note #
Is the building currently occupied?	☒	☐	☐	
Has the occupancy classification and hazard of contents remained the same since the last inspection?	☒	☐	☐	
Are all fire protection systems in service?	☒	☐	☐	
Has the system remained in service without modifications or actuations of devices/alarms since last inspection?	☒	☐	☐	
Fire pump onsite?	☒	☐	☐	

SPRINKLERS (visible)	YES	NO	N/A	Note #
Free of damage or leaks?	☒	☐	☐	
Free of corrosion, foreign material, or paint, loading?	☒	☐	☐	
Installed in proper orientation?	☒	☐	☐	
Fluid in glass bulbs?	☒	☐	☐	
Spare head box contains proper number and type of heads, including wrench(s)?	☒	☐	☐	
Escutcheon plates are present and installed correctly?	☒	☐	☐	
Minimum clearance between sprinklers and storage?	☒	☐	☐	
Sprinklers tested or replaced per appropriate testing schedule?	☒	☐	☐	

Sprinkler heads in use and earliest date on heads:

Standard: ☒ 2004 Quick Response: _____ ESFR: _____ Dry Pendant: _____

PIPING	YES	NO	N/A	Note #
In good condition with no external corrosion?	☒	☐	☐	
No leaks or mechanical damage?	☒	☐	☐	
Correct alignment/No external loads?	☒	☐	☐	
Wet Sprinkler piping not exposed to freezing temperatures?	☒	☐	☐	
Hangers/bracing not damaged or loose?	☒	☐	☐	

FIRE DEPARTMENT CONNECTIONS	YES	NO	N/A	Note #
Visible and accessible?	☒	☐	☐	
Couplings swivel and operate properly?	☒	☐	☐	
Plugs or caps in place?	☒	☐	☐	
Identification signs are in place?	☒	☐	☐	
Ball drip valve is functional/not leaking?	☒	☐	☐	

ANTI-FREEZE SYSTEMS	YES	NO	N/A	Note #
Have all anti-freeze systems been tested?	☐	☐	☒	
Proper signage and placard info in place?	☐	☐	☒	

LOCATION / AREA PROTECTED	TEMP	Note #	LOCATION / AREA PROTECTED	TEMP	Note #
1			3		
2			4		

(*Any additional anti-freeze system results will be listed in Note # Section)

<i>FIVE YEAR REQUIREMENTS</i>	YES	NO	N/A	Note #
<i>Have all Check Valves, Pre-action or Deluge Valves been internally inspected within the last 5 years?</i>	☐	☒	☐	1
<i>Has the piping in all systems been checked for obstructive materials within the last 5 years?</i>	☐	☒	☐	1
<i>System Gauges tested or replaced within the last 5 years?</i>	☒	☐	☐	2018

CONTROL VALVES	YES	NO	N/A	Note #
All Control Valves in the correct (open or closed) position?	☒	☐	☐	
Locked or supervised?	☒	☐	☐	
Easily accessible?	☒	☐	☐	
Free from damage or leaks?	☒	☐	☐	
Proper signage in place?	☒	☐	☐	
Tamper Switches operate properly?	☒	☐	☐	
All Control Valves operated through full range and return to normal position?	☒	☐	☐	
OS&Y Valves properly lubricated?	☒	☐	☐	

<i>Description</i>	<i>Type</i>	<i>Size</i>	<i>Location</i>	<i>Note #</i>
Fire pump discharge	OS&Y	6"	Sprinkler room/ mechanical room 137	
Fire pump suction	OS&Y	8"	Sprinkler room/ mechanical room 137	
City 1	OS&Y	8"	Sprinkler room/ mechanical room 137	
City 2	OS&Y	8"	Sprinkler room/ mechanical room 137	
Jockey pump suction	Butterfly	1"	Sprinkler room/ mechanical room 137	
Jockey pump discharge	Butterfly	1"	Sprinkler room/ mechanical room 137	
Bypass 1	Butterfly	6"	Sprinkler room/ mechanical room 137	
Bypass 2	Butterfly	6"	Sprinkler room/ mechanical room 137	
Test header	Butterfly	6"	Sprinkler room/ mechanical room 137	
Riser 1	Butterfly	4"	Sprinkler room/ mechanical room 137	
Riser 2	Butterfly	4"	Sprinkler room/ mechanical room 137	
2nd floor	Butterfly	4"	Housekeeping closet 243	

(*Any additional control valves will be listed on a separate sheet.)

MAIN DRAIN AND WATERFLOW TEST RESULTS	YES	NO	N/A	Note #
Do main drain test results differ more than 10% from previous test?	☐	☒	☐	

[illegible]

(*Any additional main drain/waterflow results will be listed on a separate sheet.)

Report to:**Property:** WCC, Fox Valley, 2060 Ogden Ave**Address:** 2060 Ogden Avenue**City:** Aurora**State:** IL **Zip:** 60504**Date:****Job Number:****Technician:**

Annual FIRE SPRINKLER INSPECTION REPORT

Central Station	POS/Acct	Handled by customer	Out	IN
-----------------	----------	---------------------	-----	----

GENERAL	YES	NO	N/A	Note #
Is the building currently occupied?	☒	☐	☐	
Has the occupancy classification and hazard of contents remained the same since the last inspection?	☒	☐	☐	
Are all fire protection systems in service?	☒	☐	☐	
Has the system remained in service without modifications or actuations of devices/alarms since last inspection?	☒	☐	☐	
Fire pump onsite?	☐	☒	☐	

SPRINKLERS (visible)	YES	NO	N/A	Note #
Free of damage or leaks?	☒	☐	☐	
Free of corrosion, foreign material, or paint, loading?	☒	☐	☐	
Installed in proper orientation?	☒	☐	☐	
Fluid in glass bulbs?	☒	☐	☐	
Spare head box contains proper number and type of heads, including wrench(s)?	☒	☐	☐	
Escutcheon plates are present and installed correctly?	☒	☐	☐	
Minimum clearance between sprinklers and storage?	☒	☐	☐	
Sprinklers tested or replaced per appropriate testing schedule?	☒	☐	☐	

Sprinkler heads in use and earliest date on heads:

Standard: ☒ 2009 Quick Response: _____

ESFR: _____

Dry Pendant: _____

PIPING	YES	NO	N/A	Note #
In good condition with no external corrosion?	☒	☐	☐	
No leaks or mechanical damage?	☒	☐	☐	
Correct alignment/No external loads?	☒	☐	☐	
Wet Sprinkler piping not exposed to freezing temperatures?	☒	☐	☐	
Hangers/bracing not damaged or loose?	☒	☐	☐	

FIRE DEPARTMENT CONNECTIONS	YES	NO	N/A	Note #
Visible and accessible?	☒	☐	☐	
Couplings swivel and operate properly?	☒	☐	☐	
Plugs or caps in place?	☒	☐	☐	
Identification signs are in place?	☒	☐	☐	
Ball drip valve is functional/not leaking?	☒	☐	☐	

ANTI-FREEZE SYSTEMS	YES	NO	N/A	Note #
Have all anti-freeze systems been tested?	☐	☐	☒	
Proper signage and placard info in place?	☐	☐	☒	

LOCATION / AREA PROTECTED	TEMP	Note #	LOCATION / AREA PROTECTED	TEMP	Note #
1			3		
2			4		

(*Any additional anti-freeze system results will be listed in Note # Section)

Report to:**Property:** WCC, Fox Valley, 2060 Ogden Ave**Address:** 2060 Ogden Avenue**City:** Aurora**State:** IL **Zip:** 60504**Date:****Job Number:****Technician:****Annual FIRE SPRINKLER INSPECTION REPORT**

FIVE YEAR REQUIREMENTS	YES	NO	N/A	Note #
Have all Check Valves, Pre-action or Deluge Valves been internally inspected within the last 5 years?	☐	☒	☐	
Has the piping in all systems been checked for obstructive materials within the last 5 years?	☐	☒	☐	
System Gauges tested or replaced within the last 5 years?	☒	☐	☐	2019

CONTROL VALVES	YES	NO	N/A	Note #
All Control Valves in the correct (open or closed) position?	☒	☐	☐	
Locked or supervised?	☒	☐	☐	
Easily accessible?	☒	☐	☐	
Free from damage or leaks?	☒	☐	☐	
Proper signage in place?	☒	☐	☐	
Tamper Switches operate properly?	☒	☐	☐	
All Control Valves operated through full range and return to normal position?	☒	☐	☐	
OS&Y Valves properly lubricated?	☒	☐	☐	

Description	Type	Size	Location	Note #
City 1	OS&Y	8"	Sprinkler room	
City 2	OS&Y	8"	Sprinkler room	
Basement	Butterfly	2"	Sprinkler room	
1st floor	Butterfly	3"	Staff workroom off stair 2	
2nd floor	Butterfly	3"	2nd floor stairs	

(*Any additional control valves will be listed on a separate sheet.)

MAIN DRAIN AND WATERFLOW TEST RESULTS	YES	NO	N/A	Note #
Do main drain test results differ more than 10% from previous test?	☐	☒	☐	

System #	Riser Size	Size of Test Pipe	PSI Static Pressure Before	PSI Residual Pressure	PSI Pressure After	Waterflow Time (sec)	Note #
Main riser	4"	2"	65	45	55	W/60	
1st floor	3"	>	65	45	55	W/60	
2nd floor	3"	1"	65	45	55	W/60	
Basement	2"	1"	65	45	55	W/60	

(*Any additional main drain/waterflow results will be listed on a separate sheet.)

Report to:
Property: WCC, Student Center, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL **Zip:** 60554

Date: 10/16/2021
Job Number:
Technician:

Annual FIRE SPRINKLER INSPECTION REPORT

Central Station	Handled By	POS/Acct	Building Contact	Out	IN
-----------------	------------	----------	------------------	-----	----

GENERAL	YES	NO	N/A	Note #
Is the building currently occupied?	☒	☐	☐	
Has the occupancy classification and hazard of contents remained the same since the last inspection?	☐	☐	☒	
Are all fire protection systems in service?	☒	☐	☐	
Has the system remained in service without modifications or actuations of devices/alarms since last inspection?	☐	☐	☒	
Fire pump onsite?	☐	☒	☐	

SPRINKLERS (visible)	YES	NO	N/A	Note #
Free of damage or leaks?	☒	☐	☐	
Free of corrosion, foreign material, or paint, loading?	☒	☐	☐	
Installed in proper orientation?	☒	☐	☐	
Fluid in glass bulbs?	☒	☐	☐	
Spare head box contains proper number and type of heads, including wrench(s)?	☒	☐	☐	
Escutcheon plates are present and installed correctly?	☒	☐	☐	
Minimum clearance between sprinklers and storage?	☒	☐	☐	
Sprinklers tested or replaced per appropriate testing schedule?	☐	☐	☒	

Sprinkler heads in use and earliest date on heads:

Standard: ☒ 2008 Quick Response: ☒ 2007

ESFR: _____

Dry Pendant: ☒ 2007

1

PIPING	YES	NO	N/A	Note #
In good condition with no external corrosion?	☒	☐	☐	
No leaks or mechanical damage?	☒	☐	☐	
Correct alignment/No external loads?	☒	☐	☐	
Wet Sprinkler piping not exposed to freezing temperatures?	☒	☐	☐	
Hangers/bracing not damaged or loose?	☒	☐	☐	

FIRE DEPARTMENT CONNECTIONS	YES	NO	N/A	Note #
Visible and accessible?	☒	☐	☐	
Couplings swivel and operate properly?	☒	☐	☐	
Plugs or caps in place?	☒	☐	☐	
Identification signs are in place?	☒	☐	☐	
Ball drip valve is functional/not leaking?	☒	☐	☐	

ANTI-FREEZE SYSTEMS	YES	NO	N/A	Note #
Have all anti-freeze systems been tested?	☐	☐	☒	
Proper signage and placard info in place?	☐	☐	☒	

LOCATION / AREA PROTECTED	TEMP	Note #	LOCATION / AREA PROTECTED	TEMP	Note #
1			3		
2			4		

(*Any additional anti-freeze system results will be listed in Note # Section)

Report to:
Property: WCC, Student Center, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL **Zip:** 60554

Date: 10/16/2021
Job Number:
Technician:

Annual FIRE SPRINKLER INSPECTION REPORT

<i>FIVE YEAR REQUIREMENTS</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
Have all Check Valves, Pre-action or Deluge Valves been internally inspected within the last 5 years?	☒	☐	☐	2019
Has the piping in all systems been checked for obstructive materials within the last 5 years?	☒	☐	☐	2019
System Gauges tested or replaced within the last 5 years?	☒	☐	☐	2019

<i>CONTROL VALVES</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
All Control Valves in the correct (open or closed) position?	☒	☐	☐	
Locked or supervised?	☒	☐	☐	
Easily accessible?	☒	☐	☐	
Free from damage or leaks?	☒	☐	☐	
Proper signage in place?	☒	☐	☐	
Tamper Switches operate properly?	☒	☐	☐	
All Control Valves operated through full range and return to normal position?	☒	☐	☐	
OS&Y Valves properly lubricated?	☒	☐	☐	

<i>Description</i>	<i>Type</i>	<i>Size</i>	<i>Location</i>	<i>Note #</i>
City 1	OS&Y	6"	1st flr mech rm	
City 2	OS&Y	6"	1st flr mech rm	
City 3	OS&Y	4"	1st flr mech rm	
City 4	OS&Y	4"	1st flr mech rm	
1st flr	Butterfly	3"	1st flr mech rm	
2nd flr	Butterfly	3"	1st flr mech rm	

(*Any additional control valves will be listed on a separate sheet.)

<i>MAIN DRAIN AND WATERFLOW TEST RESULTS</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
Do main drain test results differ more than 10% from previous test?	☐	☒	☐	

<i>System #</i>	<i>Riser Size</i>	<i>Size of Test Pipe</i>	<i>PSI Static Pressure Before</i>	<i>PSI Residual Pressure</i>	<i>PSI Pressure After</i>	<i>Waterflow Time (sec)</i>	<i>Note #</i>
1st flr	3"	2"	80	40	70	W/60	
2nd flr	3"	2"	80	40	70	W/60	

(*Any additional main drain/waterflow results will be listed on a separate sheet.)

Report to:
Property: WCC, Von Ohlen Hall, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL **Zip:** 60554

Date: 10/16/2021
Job Number:
Technician:

Annual FIRE SPRINKLER INSPECTION REPORT

Central Station	Handled by	POS/Acct	Contact	Out	IN
-----------------	------------	----------	---------	-----	----

GENERAL	YES	NO	N/A	Note #
Is the building currently occupied?	☒	☐	☐	
Has the occupancy classification and hazard of contents remained the same since the last inspection?	☐	☐	☒	
Are all fire protection systems in service?	☒	☐	☐	
Has the system remained in service without modifications or actuations of devices/alarms since last inspection?	☐	☐	☒	
Fire pump onsite?	☐	☒	☐	

SPRINKLERS (visible)	YES	NO	N/A	Note #
Free of damage or leaks?	☒	☐	☐	
Free of corrosion, foreign material, or paint, loading?	☒	☐	☐	
Installed in proper orientation?	☒	☐	☐	
Fluid in glass bulbs?	☒	☐	☐	
Spare head box contains proper number and type of heads, including wrench(s)?	☒	☐	☐	
Escutcheon plates are present and installed correctly?	☒	☐	☐	
Minimum clearance between sprinklers and storage?	☒	☐	☐	
Sprinklers tested or replaced per appropriate testing schedule?	☐	☐	☒	

Sprinkler heads in use and earliest date on heads:

Standard: ☒ 92 Quick Response: ☒ 2020 ESFR: _____ Dry Pendant: _____

PIPING	YES	NO	N/A	Note #
In good condition with no external corrosion?	☒	☐	☐	
No leaks or mechanical damage?	☒	☐	☐	
Correct alignment/No external loads?	☒	☐	☐	
Wet Sprinkler piping not exposed to freezing temperatures?	☒	☐	☐	
Hangers/bracing not damaged or loose?	☒	☐	☐	

FIRE DEPARTMENT CONNECTIONS	YES	NO	N/A	Note #
Visible and accessible?	☒	☐	☐	
Couplings swivel and operate properly?	☒	☐	☐	
Plugs or caps in place?	☒	☐	☐	
Identification signs are in place?	☒	☐	☐	
Ball drip valve is functional/not leaking?	☒	☐	☐	

ANTI-FREEZE SYSTEMS	YES	NO	N/A	Note #
Have all anti-freeze systems been tested?	☐	☐	☒	
Proper signage and placard info in place?	☐	☐	☒	

LOCATION / AREA PROTECTED	TEMP	Note #	LOCATION / AREA PROTECTED	TEMP	Note #
1			3		
2			4		

(*Any additional anti-freeze system results will be listed in Note # Section)

Report to:
Property: WCC, Von Ohlen Hall, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL **Zip:** 60554

Date: 10/16/2021
Job Number:
Technician:

Annual FIRE SPRINKLER INSPECTION REPORT

<i>FIVE YEAR REQUIREMENTS</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
Have all Check Valves, Pre-action or Deluge Valves been internally inspected within the last 5 years?	☐	☒	☐	1
Has the piping in all systems been checked for obstructive materials within the last 5 years?	☐	☒	☐	1
System Gauges tested or replaced within the last 5 years?	☒	☐	☐	

<i>CONTROL VALVES</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
All Control Valves in the correct (open or closed) position?	☒	☐	☐	
Locked or supervised?	☒	☐	☐	
Easily accessible?	☒	☐	☐	
Free from damage or leaks?	☒	☐	☐	
Proper signage in place?	☒	☐	☐	
Tamper Switches operate properly?	☒	☐	☐	
All Control Valves operated through full range and return to normal position?	☒	☐	☐	
OS&Y Valves properly lubricated?	☒	☐	☐	

<i>Description</i>	<i>Type</i>	<i>Size</i>	<i>Location</i>	<i>Note #</i>
System before backflow	OS&Y	2 1/2"	NW corner by stair - 122A	
System after backflow	OS&Y	2 1/2"	NW corner by stair - 122A	

(*Any additional control valves will be listed on a separate sheet.)

<i>MAIN DRAIN AND WATERFLOW TEST RESULTS</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
Do main drain test results differ more than 10% from previous test?	☐	☒	☐	

<i>System #</i>	<i>Riser Size</i>	<i>Size of Test Pipe</i>	<i>PSI Static Pressure Before</i>	<i>PSI Residual Pressure</i>	<i>PSI Pressure After</i>	<i>Waterflow Time (sec)</i>	<i>Note #</i>
Riser	2 1/2"	1 1/4"	110	60	70	W/60	

(*Any additional main drain/waterflow results will be listed on a separate sheet.)



Pyro Fire Protection Inc.

P.O. Box 219 Westmont, IL 60559

Tel: 630-329-9511 Email: goran@pyrofireprotection.com

HYDRANT FLUSH REPORT

Customer: Waubesa Community College

Address: 4S783 State Route 47

City, State, Zip: Sugar Grove, IL 60554

Date: 7/16/2018

Location	# of Outlets	Outlet Sizes	Threaded / Storz	Flowed Y / N	Barrell Drained after Flush Y / N
100' South of Bodie Hall	3	2 x 2 1/2" 1 x 4"	Threaded	YES	YES
60' South of Dickson Center	3	2 x 2 1/2" 1 x 4"	Threaded	YES	YES
20' off the N.E. Corner of Dickson Center	3	2 x 2 1/2" 1 x 4"	Threaded	YES	YES
90' off the N.E. corner of Building A	3	2 x 2 1/2" 1 x 4"	Threaded	YES	YES
50' off the east face of Henning	3	2 x 2 1/2" 1 x 4"	Threaded	YES	YES
75' off the S.W. corner of Akerlow	3	2 x 2 1/2" 1 x 4"	Threaded	YES	YES
60' Off the north face of Collins Hall	3	2 x 2 1/2" 1 x 4"	Threaded	YES	YES
100' off the N.E. corner of Erickson	3	2 x 2 1/2" 1 x 4"	Threaded	YES	YES
120' off the S.W. corner of Collins	3	2 x 2 1/2" 1 x 4"	Threaded	YES	YES
80' off the west corner of Well House	3	2 x 2 1/2" 1 x 4"	Threaded	YES	YES
50' off S.W. corner of OPS Building	3	2 x 2 1/2" 1 x 4"	Threaded	YES	YES
20' off North wall of OPS	3	2 x 2 1/2" 1 x 4"	Threaded	YES	YES
75' of N.E. Corner of Science Bldg	3	2 x 2 1/2" 1 x 4"	Threaded	YES	YES
60' of N.W. corner of Science Bldg	3	2 x 2 1/2" 1 x 4"	Threaded	YES	YES

Findings/Deficiencies/Comments:

[Handwritten signature]

8-5-19



Pyro Fire Protection Inc.
P.O. Box 219 Westmont, IL 60559
Tel: 630-329-9511 Email: goran@pyrofireprotection.com

HYDRANT FLUSH REPORT

Customer: Waubensee Community College

Address: 4S783 State Route 47

City, State, Zip: Sugar Grove, IL 60554

Date: 7/16/2018

Location	# of Outlets	Outlet Sizes	Threaded / Storz	Flowed Y / N	Barrell Drained after Flush Y / N
50' of N.E. corner of APC Building	3	2 x 2 1/2" 1 x 4"	Threaded	YES	YES
50' of N.W. corner of APC Building	3	2 x 2 1/2" 1 x 4"	Threaded	YES	YES
180' of S.E. corner of Student Cntr	3	2 x 2 1/2" 1 x 4"	Threaded	YES	YES
N1 Parking Lot South	3	2 x 2 1/2" 1 x 4"	Threaded	YES	YES
N1 Parking Lot North	3	2 x 2 1/2" 1 x 4"	Threaded	YES	YES
N.W. Corner of Student Center	3	2 x 2 1/2" 1 x 4"	Threaded	YES	YES
South East Corner of Field House	3	2 x 2 1/2" 1 x 4"	Threaded	YES	YES

Findings/Deficiencies/Comments:

[Signature] 8-5-19

Executive Summary

Generated by: BuildingReports.com

Building Information

Building: Waubonsee Plano

Contact: Ed Plante

Address: 100 Waubonsee Dr

Phone: 630-446-7900

Address:

Fax:

City/State/Zip: Plano, IL 60545

Mobile:

Country: United States of America

Email:

Inspection Performed By

System Control Unit

System Type	System Location	Protected Area	Devices
Wet Pipe	1st floor	Riser 1	6
Wet Pipe	2nd floor	Riser 2	6
Wet Pipe	Building-	Building-	9

Inspection Summary

Category	Total Items		Serviced		Passed		Failed/Other	
	Qty	%	Qty	%	Qty	%	Qty	%
Device	4	19.05%	4	100.00%	4	100.00%	0	0%
Alarm	7	33.33%	7	100.00%	7	100.00%	0	0%
Valve	8	38.10%	8	100.00%	8	100.00%	0	0%
Sprinkler	2	9.52%	2	100.00%	2	100.00%	0	0%
Totals	21	100%	21	100.00%	21	100.00%	0	0%

Certification

Building: Waubonsee Plano

Contact: Ed Plante

Signed:

Signed:

Inspection & Testing

Generated by: BuildingReports.com

Building: Waubonsee Plano				
The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.				
Device Type	Location	Service	Time	Date
Passed				
1st floor Wet Pipe, Riser 1				
Tamper Switch	sprinkler room Riser 1	Annual	11:33:58 AM	08/01/2019
Waterflow Switch	sprinkler room Riser 1	Annual	11:58:01 AM	08/01/2019
Drain	sprinkler room Riser 1	Annual	11:39:07 AM	08/01/2019
Gauge	sprinkler room Riser 1	Annual	11:35:35 AM	08/01/2019
Control Valve	sprinkler room Riser 1	Annual	11:34:10 AM	08/01/2019
Inspector's Test	in ceiling tile by room 129	Annual	11:58:16 AM	08/01/2019
2nd floor Wet Pipe, Riser 2				
Tamper Switch	sprinkler room Riser 2	Annual	11:33:38 AM	08/01/2019
Waterflow Switch	sprinkler room Riser 1	Annual	12:07:19 PM	08/01/2019
Drain	sprinkler room Riser 2	Annual	11:39:17 AM	08/01/2019
Gauge	sprinkler room Riser 2	Annual	11:35:22 AM	08/01/2019
Control Valve	sprinkler room Riser 2	Annual	11:33:54 AM	08/01/2019
Inspector's Test	by roof access door	Annual	12:03:14 PM	08/01/2019
Building– Wet Pipe, Building–				
Tamper Switch	sprinkler room City side backflow	Annual	11:34:23 AM	08/01/2019
Tamper Switch	sprinkler room System side backflow	Annual	11:34:43 AM	08/01/2019
Tamper Switch	sprinkler room FDC Drain	Annual	11:37:48 AM	08/01/2019
Sprinkler Box	in sprinkler room On wall	Annual	11:35:17 AM	08/01/2019
Sprinkler Box Spares	in sprinkler room On wall	Annual	11:35:15 AM	08/01/2019
Check Valve	sprinkler room FDC	Annual	11:35:51 AM	08/01/2019
Control Valve	sprinkler room City side backflow	Annual	11:34:33 AM	08/01/2019
Control Valve	sprinkler room System side backflow	Annual	11:34:56 AM	08/01/2019
Control Valve	sprinkler room FDC Drain	Annual	11:37:52 AM	08/01/2019

Wet Pipe Fire Sprinkler Systems

Generated by: BuildingReports.com

Building: Waubensee Plano				1st floor, Riser 1				
<i>This section lists out all the devices and components that have been associated with a Wet Pipe System and provides details as to type of component, pressure readings, response time, etc. If a component has an OK checkbox that is checked, then that component was actually tested. However, for Pass/Fail test results, see the Inspection and Testing section.</i>								
Alarms								
Tamper Switch								
Type	Description	Manufacturer	Zone/Address	OK	ScanID			
Control Valve	Supervisory	NIBCO	1	☒	43926833			
Waterflow Switch								
Type	Manufacturer	Model #	Sec	Size	Zone/Address	OK	ScanID	
Vane	System Sensor	WFD 40	37	4	1	☒	43926839	
Components								
Control Valve								
Type	Manufacturer	Model	Location	Size	Position	Status	OK	ScanID
Butterfly	NIBCO	GD-4765-8N	sprinkler room Riser 1	4"	Open	Supervised	☒	43926835
Description								
Isolation								
Inspector's Test								
Manufacturer	Model #	Pressure psi	Trip Time Sec	Flow Sec	OK	ScanID		
Vi		75		37	☒	43926794		
Devices								
Drain								
Current Inspection								
Type	Location	Size	Supply psi	Static psi	Residual psi	Sec	OK	ScanID
Main	sprinkler room Riser 1	2"	75	75	55	20	☒	43926837
Previous Inspections								
July 19, 2018								
Type	Location	Size	Supply psi	Static psi	Residual psi	Sec	OK	ScanID
Main	sprinkler room Riser 1	2"	75	75	55	3	☒	43926837
Gauge								
Location				Service Date				
sprinkler room Riser 1				07/19/2020				
Type	Mfr/Model	Static psi	Fill Type	Size	OK	ScanID		
System Pressure	Vi /	75	n/a	1 / 4	☒	43926840		

Building: Waubensee Plano				2nd floor, Riser 2				
<i>This section lists out all the devices and components that have been associated with a Wet Pipe System and provides details as to type of component, pressure readings, response time, etc. If a component has an OK checkbox that is checked, then that component was actually tested. However, for Pass/Fail test results, see the Inspection and Testing section.</i>								
Alarms								
Tamper Switch								
Type	Description	Manufacturer	Zone/Address	OK	ScanID			
Control Valve	Supervisory	NIBCO	1	☒	43926832			
Waterflow Switch								
Type	Manufacturer	Model #	Sec	Size	Zone/Address	OK	ScanID	
Vane	System Sensor	WFD 40	42	4	1	☒	43926838	
Components								
Control Valve								
Type	Manufacturer	Model	Location	Size	Position	Status	OK	ScanID
Butterfly	NIBCO	GD-4765-8N	sprinkler room Riser 2	4"	Open	Supervised	☒	43926834
Description								
Isolation								
Inspector's Test								
Manufacturer	Model #	Pressure psi	Trip Time Sec	Flow Sec	OK	ScanID		
Vi		75		42	☒	43926793		
Devices								
Drain								
Current Inspection								
Type	Location	Size	Supply psi	Static psi	Residual psi	Sec	OK	ScanID
Main	sprinkler room Riser 2	2"	75	75	55	20	☒	43926836
Previous Inspections								
July 19, 2018								
Type	Location	Size	Supply psi	Static psi	Residual psi	Sec	OK	ScanID
Main	sprinkler room Riser 2	2"	75	75	55	3	☒	43926836
Gauge								
Location				Service Date				
sprinkler room Riser 2				07/19/2020				
Type	Mfr/Model	Static psi	Fill Type	Size	OK	ScanID		
System Pressure	Vi /	75	n/a	1 / 4	☒	43926841		

Building: Waubensee Plano				Building-, Building-				
<i>This section lists out all the devices and components that have been associated with a Wet Pipe System and provides details as to type of component, pressure readings, response time, etc. If a component has an OK checkbox that is checked, then that component was actually tested. However, for Pass/Fail test results, see the Inspection and Testing section.</i>								
Alarms								
Tamper Switch								
Type	Description	Manufacturer	Zone/Address	OK	ScanID			
OS&Y	Supervisory	System Sensor	1	☒	43926844			
OS&Y	Supervisory	System Sensor	1	☒	43926842			
Control Valve	Supervisory	NIBCO	1	☒	43926846			
Components								
Check Valve								
Type	Location	Internal Date		Size	OK	ScanID		
Grooved	sprinkler room FDC	07/19/2018		4"	☒	43926848		
Control Valve								
Type	Manufacturer	Model	Location	Size	Position	Status	OK	ScanID
OS&Y	Kennedy	KS2	sprinkler room City side backflow	4"	Open	Supervised	☒	43926845
Description								
Main Control								
Control Valve								
Type	Manufacturer	Model	Location	Size	Position	Status	OK	ScanID
OS&Y	Kennedy	KS2	sprinkler room System side backflow	4"	Open	Supervised	☒	43926843
Description								
Main Control								
Control Valve								
Type	Manufacturer	Model	Location	Size	Position	Status	OK	ScanID
Butterfly	NIBCO	GD-4765-8N	sprinkler room FDC Drain	2.5"	Closed	Supervised	☒	43926847
Description								
Isolation								
Devices								
Sprinkler Box								
Qty	Tool Available?	Size	Manufacturer	Location		OK	ScanID	
12	Yes	6 unit		in sprinkler room On wall		☒	43926831	
Sprinkler Box Spares								
Qty	Type	KFactor	Manufacturer	Location		OK	ScanID	

Inventory & Warranty Report

Generated by: BuildingReports.com

Building: Waubonsee Plano

The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.

Device or Item	Category	% of Inventory		Quantity	
Tamper Switch	Alarm	23.81%		5	
Control Valve	Valve	23.81%		5	
Sprinkler Box Spares	Sprinkler	4.76%		1	
Sprinkler Box	Sprinkler	4.76%		1	
Gauge	Device	9.52%		2	
Check Valve	Valve	4.76%		1	
Drain	Device	9.52%		2	
Waterflow Switch	Alarm	9.52%		2	
Inspector's Test	Valve	9.52%		2	
Device or Item	Qty	Model #	Type	Description	Install Date
<i>In Service - 3 Years to 5 Years</i>					
1st floor Wet Pipe, Riser 1					
Gauge	1			System Pressure	01/01/2015
2nd floor Wet Pipe, Riser 2					
Gauge	1			System Pressure	01/01/2015
<i>In Service - 5 Years to 10 Years</i>					
1st floor Wet Pipe, Riser 1					
Inspector's Test	1				01/01/2013
2nd floor Wet Pipe, Riser 2					
Inspector's Test	1				01/01/2013
Building- Wet Pipe, Building-					
Sprinkler Box	1				01/01/2013
Sprinkler Box Spares	1	F1	Pendant		01/01/2013
<i>In Service - 10 Years to 15 Years</i>					
2nd floor Wet Pipe, Riser 2					
Waterflow Switch	1	WFD 40	Vane	Alarm	01/02/2006
1st floor Wet Pipe, Riser 1					
Drain	1		Main		01/01/2006
Control Valve	1	GD-4765-8N	Butterfly	Isolation	01/01/2006
Tamper Switch	1	GD-4765-8N	Control Valve	Supervisory	01/01/2006
Waterflow Switch	1	WFD 40	Vane	Alarm	01/01/2006
2nd floor Wet Pipe, Riser 2					
Drain	1		Main		01/01/2006
Control Valve	1	GD-4765-8N	Butterfly	Isolation	01/01/2006

<i>In Service - 10 Years to 15 Years</i>					
Tamper Switch	1	GD-4765-8N	Control Valve	Supervisory	01/01/2006
Building- Wet Pipe, Building-					
Control Valve	2	KS2	OS&Y	Main Control	01/01/2006
Control Valve	1	GD-4765-8N	Butterfly	Isolation	01/01/2006
Tamper Switch	1	GD-4765-8N	Control Valve	Supervisory	01/01/2006
Check Valve	1	C	Grooved		01/01/2006
Tamper Switch	2	OSY2	OS&Y	Supervisory	01/01/2006



1615 S.W. Adams St.
Peoria, IL 61602
Ph: (309) 673-0761
www.getzfire.com

Annual Fire Sprinkler System - Inspection & Test Report

Inspection Date:	8/10/2016	System Name or #:	Bodie	Occupancy Type:	Education Group E
Customer Site #:	56059-03	Date of I&T Agreement:		End of I&T Agreement:	
Facility Name:	Waubonsee Community College	Facility Address:	Route 47 at Waubonsee Dr.	Site Contact:	Ed Plante
City:	Sugar Grove	State:	IL	Zip:	60554
		Phone #:	30-816-6384	E-Mail:	eplante@waubonsee.edu

General Requirements				YES	N/A	NO	A
Areas with non protected water filled pipes, min 40°F.....	☐	☒	☐	1			
All components accessible.....	☒	☐	☐	2			
System, facility, or use free of changes requiring an evaluation.....	☒	☐	☐	3			
Location of shutoff valves identified.....	☐	☒	☐	4			
Information signs provided for risers feeding dry, pre-action, anti-freeze, & aux. system valves.....	☐	☐	☒	5			
Past inspection and testing records available.....	☒	☐	☐	6			
As-built drawings, hydraulic calcs, acceptance records, and device data sheets available.....	☒	☐	☐	7			
All Components free of damage and function properly.....	☐	☐	☒	8			
All components in full operational condition.....	☒	☐	☐	9			

Notifications				YES	N/A	NO	B
Facility representative notified of testing.....	☐	☒	☐	1			
Before: Name and Time:							
After: Name and Time:							
Facility Occupants notified of testing.....	☒	☐	☐	2			
Before: Name and Time:							
After: Name and Time:							
Monitoring company notified of testing.....	☒	☐	☐	3			
Before: Name and Time:	Acadian						
After: Name and Time:	Acadian						
AHJ or Fire Department, if required, notified of testing.....	☒	☐	☐	4			
Before: Name and Time:	Campus Police						
After: Name and Time:	Campus Police						

Sprinkler Systems				YES	N/A	NO	C
Sprinklers free of leakage, corrosion, damage, loss of fluid, loading, paint, and incorrect orientation.....	☐	☐	☒	1			
Sprinklers normally not accessible for safety reasons have been inspected.....	☐	☒	☐	2			
Flush, concealed, and recessed sprinkler escutcheons in place.....	☐	☐	☒	3			
Proper distance from deflector to storage maintained.....	☒	☐	☐	4			
All piping and fittings in good condition.....	☒	☐	☐	5			
Piping free from external loads.....	☒	☐	☐	6			
Piping normally not accessible for safety reasons has been inspected.....	☐	☒	☐	7			

Sprinkler Systems Continued				YES	N/A	NO	C
Hangers and bracing in good condition.....	☒	☐	☐	8			
Hangers and bracing normally not accessible for safety reason has been inspected.....	☐	☒	☐	9			
Both gauges on freezer air lines show similar readings.....	☐	☒	☐	10			
Waterflow and supervisory devices free of damage.....	☒	☐	☐	11			
Hydraulic/pipe schedule design sign in place.....	☐	☐	☒	12			
General information sign provided if required (new 2010).....	☐	☒	☐	13			
Sprinklers in service for 50 years replaced or tested.....	☐	☒	☐	14			
Date tested or replaced. Testing every 10 years after.....							
Sprinklers manufactured prior to 1920 replaced.....	☐	☒	☐	15			
Fast response sprinklers in service for 20 years replaced or tested.....	☐	☒	☐	16			
Date tested or replaced. Testing every 10 years after.....							
Extra high temp sprinklers replaced or tested at 5 years.....	☐	☒	☐	17			
Date tested or replaced.....							
Sprinklers in service for 75 years replaced or tested.....	☐	☒	☐	18			
Date tested or replaced. Testing every 5 years after.....							
Dry sprinklers replaced or tested every 10 years.....	☐	☒	☐	19			
Date tested or replaced.....							
Sprinklers in harsh environments replaced or tested every 5 years.....	☐	☒	☐	20			
Date tested or replaced.....							
Gauges replaced or calibrated every 5 years.....	☒	☐	☐	21			
Date tested or replaced.....	3/18/2013						
Gauges accurate within 3% of full scale.....	☒	☐	☐	22			
Gauges in good condition.....	☒	☐	☐	23			
Spare sprinklers are all new and have not been used.....	☒	☐	☐	24			
Spare sprinklers are of the proper type.....	☒	☐	☐	25			
The proper amount of spare sprinklers is provided.....	☒	☐	☐	26			
Sprinkler cabinet location less than 100°F.....	☒	☐	☐	27			
Means of returning a system to service with dry sprinklers of different lengths is provided.....	☐	☒	☐	28			
Proper sprinkler wrenches are provided.....	☒	☐	☐	29			
List of sprinklers installed and quantity of each needed is posted in the sprinkler cabinet.....	☒	☐	☐	30			
Sprinklers protecting commercial cooking equipment and ventilating systems replaced annually or cleaned.....	☐	☒	☐	31			
Protective covers for spray areas and mixing rooms in place and free of accumulation.....	☐	☒	☐	32			
Waterflow switches tested.....	☒	☐	☐	33			

This inspection was completed in compliance with the requirements of NFPA 25, 2014 edition. Consult with your local AHJ (Authority Having Jurisdiction), about differences in the standards that they might enforce.

Ed Plante	Rob Stecken / NICET Level 3 / 126117
Owner/Owner Representative (sign & print)	Technician / NICET Level / NICET Certification Number

IL. Sprinkler Lic. #
FSC0104

Protecting Life & Property is Priority One

IL. Plumbing Lic. #
055-043894



N/A ☒ <u>Antifreeze</u> YES N/A NO Antifreeze is identifiable and of the correct type..... ☐ ☐ ☐ 1 Samples have been taken from required locations..... ☐ ☐ ☐ 2 Specific gravity from samples within acceptable range..... ☐ ☐ ☐ 3 Antifreeze solution adequate to prevent freezing..... ☐ ☐ ☐ 4 Only glycerin used in CPVC piping..... ☐ ☐ ☐ 5 Antifreeze solution is listed or meets exemption requirement for service until 2022..... ☐ ☐ ☐ 6	N/A ☒ <u>Alarm Valves</u> YES N/A NO H Gauges indicate normal water pressure..... ☐ ☐ ☐ 1 Valve is free of physical damage..... ☐ ☐ ☐ 2 All valves are in the appropriate position..... ☐ ☐ ☐ 3 The retard chamber or alarm drain is free of leaks..... ☐ ☐ ☐ 4 Alarm valve, strainers, filters, and restricted orifices 5 year internal inspection is current..... ☐ ☐ ☐ 5 Date of inspection.....
N/A ☐ <u>Internal Piping Condition Investigation</u> YES N/A NO E Piping 5 year internal condition investigation current..... ☐ ☐ ☒ 1 Date of Investigation..... unknown Inspection and testing free of conditions requiring an obstruction investigation..... ☒ ☐ ☐ 2 Ice obstruction investigation performed annually on all penetrations into cold storage areas..... ☐ ☒ ☐ 3 Ice obstruction investigation shows piping free of ice..... ☐ ☒ ☐ 4	N/A ☒ <u>Dry Pipe Valves</u> YES N/A NO I Low temperature alarm free of damage..... ☐ ☐ ☐ 1 Low temperature alarm tested successfully..... ☐ ☐ ☐ 2 Low air alarm tested acceptably..... ☐ ☐ ☐ 3 Supply side gauge indicates normal..... ☐ ☐ ☐ 4 System side air gauges indicates correct ratio..... ☐ ☐ ☐ 5 Quick opening device gauge same as system side..... ☐ ☐ ☐ 6 Air maintenance device operates properly..... ☐ ☐ ☐ 7 Air supply capable of restoring pressure within 30 minutes..... ☐ ☐ ☐ 8 Air supply for freezers maintained below 5°F restored within 60 minutes..... ☐ ☐ ☐ 9 Dry pipe system 3 year pressure test current..... ☐ ☐ ☐ 10 Date of last test..... Dry pipe system 3 year pressure test acceptable..... ☐ ☐ ☐ 11 Dry pipe system with auxiliary drains provided has a sign indicating location and number of drains..... ☐ ☐ ☐ 12 Auxiliary drains all drained..... ☐ ☐ ☐ 13 Valve free of physical damage..... ☐ ☐ ☐ 14 Inspection of valve interior performed..... ☐ ☐ ☐ 15 All trim valves in appropriate position..... ☐ ☐ ☐ 16 Priming water level is normal..... ☐ ☐ ☐ 17 Intermediate chamber is free of leaks..... ☐ ☐ ☐ 18 Quick opening device tested successfully..... ☐ ☐ ☐ 19 Dry pipe valve 3 year full trip requirement current..... ☐ ☐ ☐ 20 Date of last full trip..... Dry pipe valve annual trip requirement current..... ☐ ☐ ☐ 21 5 year internal inspection of strainers, filters, restricted orifices, and diaphragm chambers is current..... ☐ ☐ ☐ 22 Date of inspection..... Tag or card attached to valve indicating last trip..... ☐ ☐ ☐ 23
N/A ☐ <u>Valves - General</u> YES N/A NO F All control valves provided with the proper identification..... ☒ ☐ ☐ 1 All control valves protected & accessible..... ☒ ☐ ☐ 2 All control valves in normal position..... ☒ ☐ ☐ 3 All control valves Sealed, Locked, and/or Elec. Supervised..... ☒ ☐ ☐ 4 Control valve tamper switches free of damage..... ☒ ☐ ☐ 5 Supervisory signal indicates movement from normal within requirements and only restores when normal..... ☒ ☐ ☐ 6 All control valves free from external leaks..... ☒ ☐ ☐ 7 All control valves operated through its full range..... ☒ ☐ ☐ 8 Valve status test performed on all control valves..... ☒ ☐ ☐ 9 PIV's are provided with correct wrench..... ☐ ☒ ☐ 10 PIV spring test is acceptable..... ☐ ☒ ☐ 11 Main drain test performed on each water supply..... ☒ ☐ ☐ 12 Main drain test residual pressure within 10% of original acceptance, or previous test..... ☒ ☐ ☐ 13	N/A ☐ <u>Check Valves</u> YES N/A NO J Check valve 5 year inspection current..... ☐ ☐ ☒ 1 Date of inspection..... unknown N/A ☐ <u>Backflow Prevention Assemblies</u> YES N/A NO K Valves are in the open position..... ☒ ☐ ☐ 1 RPA's and RPDA's are free of leaks from relief port..... ☒ ☐ ☐ 2 Backflow prevention assembly 5 year internal inspection is current..... ☐ ☐ ☒ 3 Date of inspection..... Forward flow test performed annually..... ☒ ☐ ☐ 4 Date of last State required backflow prevention test..... 12/16/2015
N/A ☐ <u>Fire Department Connection</u> YES N/A NO G FDC is visible and accessible..... ☒ ☐ ☐ 1 Coupling or swivel free of damage and rotate smoothly..... ☒ ☐ ☐ 2 Plugs or caps are in place and free of damage..... ☒ ☐ ☐ 3 Gaskets are in place and in good condition..... ☒ ☐ ☐ 4 Identification signs are in place..... ☒ ☐ ☐ 5 The check valve holds tight..... ☒ ☐ ☐ 6 Automatic drain valve in place and operates properly..... ☒ ☐ ☐ 7 Clapper(s) are in place and operate properly..... ☒ ☐ ☐ 8 Interior of the connection is free of obstructions..... ☒ ☐ ☐ 9 5 Year hydrostatic test of the piping from the FDC to the FDC check valve is current..... ☐ ☐ ☒ 10 Date of Test..... Hydrostatic test pressure maintained for 2 hours..... ☐ ☒ ☐ 11	



1615 S.W. Adams St.
Peoria, IL. 61602
Ph: (309) 673-0761
www.getztire.com

Annual Test Results	Riser Info.	System Number		1st floor	2nd floor	Elevator Pre-Action	
		Location / Description		riser closet	stairwell ceiling	2nd floor elevator	
		System Type		wet	wet	Pre-Action	
	Control Valve	Size (in)		2 1/2"	3"	1 1/2"	
		Control Valve Manufacturer		milwaukee	kennedy	milwaukee	
		Control Valve Type		butterfly	butterfly	butterfly	
		Control Valve Condition		ok	ok	ok	
		Sign Provided?		yes	yes	yes	
		Supervised / Locked / Sealed?		supervised	supervised	supervised	
		Supervisory Device Tested OK?		yes	yes	yes	
	Main Drain / Valve Status Test	Drain Valve Location		riser	riser	riser	
		Valve Condition		ok	ok	ok	
		Static Pressure Before Test		59	75	60	
		Residual Pressure		45	56	40	
		Static Pressure After Test		65	70	60	
		Test Results Satisfactory?		yes	yes	yes	
	Alarm Test			closet of room	riser		
		Test Valve Location		147	stairwell ceiling	none	
		Test Valve Condition		ok	ok		
	Alarms Operated Yes / No / Time		38	57			
	Special Valve	Valve Type				deluge	
		Valve Manufacturer				viking	
		Model				E1	
		Size (in)				1 1/2"	
		Valve Condition				ok	
	Dry Pipe, Preaction, Deluge Valve Trip Test	Date of Last Full Trip Test				n/a	
		Date of Last Partial Trip Test				8/10/2016	
		Date of Last Pre-Action / Dry Air Test				n/a	
		Pressure Before Test	Air:				
			Water:			60	
		Tripped At	Air Pressure:			N/A	
			Time:				
		Time for Water to Reach Test Outlet					
		Pressure at Deluge Valve					
		Pressure at Remote Nozzle					
		Low Air Alarm Received at Pressure					
		Alarms Operated with Bypass?				yes	
		Valve reset After Tripped?				yes	
	Quick Opening Device	Manufacturer					
		Model					
Air Pressure Before Test							
Condition / Performance							
Device Reset After Tripped?							
Device Left In Service							
Anti-Freeze	Antifreeze Type						
	Antifreeze Concentration						
	Antifreeze Protection Temperature						

IL. Sprinkler Lic. #
FSC0104

Protecting Life & Property is Priority One

IL. Plumbing Lic. #
055-043894



DEFICIENCIES, COMMENTS AND ADDITIONAL NOTES

A5-no signage installed indicating a pre-action is installed and where it serves

A8-no inspector test valve has been installed for the pre-action system

C1-Physical damage(bent deflector)-room 150 3rd row

Physical damage, sprinkler under duct in south penthouse has been hit and is bent

Painted-penthouse(both)

C3-Missing escutcheon-west stair entrance, outside 107, 2nd floor hall outside 222 and 225, room 204b

C12-a hydraulic nameplate is not provided for the pre-action system

E1-5yr internal pipe inspection is not current

G10-5yr FDC hydrostatic test is not current(this is new to NFPA 25 per the 2014 edition)

J1-5yr internal check valve inspection is not current

K3-5yr internal backflow device inspection is not current(this is new to NFPA 25 per the 2014 edition)

TERMS AND CONDITIONS

DEFINITIONS

The words and phrases set off by quotation marks in this section of this Agreement shall have the meanings indicated.

"Agreement" means this Agreement for Providing Services, these terms and conditions, and all attachments thereto.

"Buyer" means the person or organization named as Buyer on the face of this Agreement.

"Premises" means the location where the Services are provided as indicated on the face of this Agreement.

"Purchase Price" means the cost of the Services as set forth on the face of this Agreement.

"Seller" means Getz Fire Equipment Co. d/b/a Getz Global Innovators.

"Services" means the activities to be performed by Seller under this Agreement.

Whenever a word or phrase which is used in this Agreement is defined in the Code, such word or phrase shall have the same meaning as defined in the Code unless the Code definition is consistent with the definitions herein.

WARRANTY AND WARRANTY PROCEDURE: SELLER WARRANTS THAT ALL SERVICES WILL BE PROVIDED IN A GOOD AND WORKMANLIKE MANNER. THIS WARRANTY SHALL BE VOID IF BUYER, OR ANY PERSON CLAIMING THROUGH BUYER OR EMPLOYED BY BUYER: (A) FAILS TO FOLLOW THE MANUFACTURER'S OR SELLER'S INSTRUCTIONS REGARDING MAINTENANCE OF THE PRODUCTS INSPECTED AS SET FORTH IN THIS AGREEMENT OR OTHERWISE; (B) FAILS TO EXERCISE REASONABLE CARE IN THE OPERATION OR USE OF THE PRODUCTS INSPECTED; AND/OR (C) ALTERS, MODIFIES OR IMPROPERLY REPAIRS THE PRODUCTS INSPECTED.

WARRANTY EXCLUSION: THE FOREGOING WARRANTIES ARE IN LIEU OF AND EXCLUDE ALL OTHER WARRANTIES NOT EXPRESSLY SET FORTH HEREIN WHETHER EXPRESS OR IMPLIED, BY OPERATION OF LAW OR OTHERWISE INCLUDING, BUT NOT LIMITED TO, ANY WARRANTIES RELATIVE TO PATENT INFRINGEMENT AND ANY IMPLIED WARRANTIES OF MERCHANTABILITY, AND FITNESS FOR A PARTICULAR PURPOSE.

INTENT OF INSPECTION: Any inspection or testing performed by Seller as Services is not intended to be a code review, or a complete system or code compliance evaluation.

PAYMENT AND SELLER'S REMEDIES: All amounts due from Buyer to Seller pursuant to this Agreement shall be paid according to this Agreement. Any amounts not paid when due shall bear interest at the lesser of the rate of one and a half percent (1 ½%) per month (which is 18% per year) or the maximum allowable by law. All charges of whatsoever kind of nature assessed against Seller by any bank or other financial institution in connection with payments due from Buyer to Seller shall be paid to Seller by Buyer on demand as an addition to the Purchase Price. In the case that the Services have been provided, Seller may recover the Purchase Price and expenses. Seller's expenses in any case shall include litigation expenses, reasonable attorneys' fees, and liabilities in connection with, arising out of, or relating to this Agreement and any other costs of enforcing its rights.

Seller shall have the right to withhold Services covered by this Agreement, or any other existing agreement between Seller and Buyer, in the event Buyer fails to make payment when due under any agreement between Buyer and Seller.

RISK OF LOSS; SHIPMENT; DELIVERY DATES; PARTIAL SHIPMENTS: Seller shall not be liable for loss or damage due to delay in providing the Services resulting from any cause beyond Seller's reasonable control, including, but not limited to, compliance with any regulations, orders, or instructions of any Federal, State, Municipal or other government or any department or agency thereof, acts of God, acts or omissions of Buyer, acts or civil or military authority, fires, strikes, factory shutdowns, or alterations, embargoes, war, riot, delays in transportation, or delays in manufacturing.

TAXES AND OTHER LEVIES: If any tax, public charge, tariff, duty, or increase therein, other than the Seller's income taxes, is now, or shall be assessed, levied, or imposed upon the Services to be provided, or upon any sale, delivery or other action taken hereunder, the burden of such charge shall be borne by Buyer.

BUYER RESPONSIBILITIES:

a. Buyer shall provide electrical power to portable electric tools, sufficient light, elevator service for both personnel and material where required, and reasonable cooperation of its employees.

Buyer shall assist Seller's personnel to store tools and materials in locations reasonably convenient to the installation site and not subject to pilferage. In addition, a 120 VAC 15 AMP separate circuit must be supplied within 10 feet of Seller's control panel.

b. If a fire sprinkler system is being inspected, Buyer shall be responsible for maintaining adequate heat throughout the Premises to prevent freezing or damage to the existing fire sprinkler system.

c. If a fire sprinkler system is being inspected, Buyer understands and expressly acknowledges that fire protection systems are susceptible to damage by water intrusion, ice, or other conditions inside the piping that Seller cannot detect upon inspection. In the event that water, ice, or other conditions occur which render the fire protection system inoperable or damaged, Seller expressly disclaims any responsibility for such conditions, and assumes no responsibility to investigate the cause, source or extent of such condition.

d. Buyer acknowledges this warning, and acknowledges that under NFPA and other applicable codes and regulations, it is the responsibility of the Buyer to maintain the fire protection system, including but not limited to ensuring proper drainage. Failure to properly maintain or drain the fire protection system may lead to breaks or other conditions that may render the fire protection system inoperable, or that damage to the fire protection system may result in injury, damage to property and loss of use.

REPAIR: Seller shall not be obliged to repair or redecorate due to spalling of concrete or plaster, installation of piping, conduit, raceways, cylinders, wiring or mounting of control equipment or for any other reasons, unless expressly otherwise stated.

DAMPENING: Dampening and air control will be the Buyer's responsibility.

CONCENTRATION TEST: A full or partial discharge concentration test, if required, will not be made unless specifically stated in this Agreement. To assure sufficient concentration levels in accordance with requirements of the authorities having jurisdiction, room integrity (tightness) of the area where the products to be inspected are located shall be Buyer's sole responsibility. If additional discharge concentration tests are necessary due to failure of Buyer to assure room integrity (tightness) of the area where the products to be inspected are located or for any other reason in the control of or the responsibility of Buyer, the expense of such additional tests shall be added to the Purchase Price.

LABOR CHARGES: The Purchase Price includes labor charges for labor performed during the Seller's ordinary business hours. If the Buyer requires the Seller to perform work after ordinary business hours or on weekends, any overtime compensation paid by the Seller to its employees and by the Seller's subcontractors to the subcontractors' employees shall become an addition to the Purchase Price and shall be paid by Buyer.

TIME LIMITATION: All claims, actions or proceedings, legal or equitable, against Seller must be commenced in court within one (1) year after the cause of action has accrued, or the act, omission or event occurred from which the claim, action or proceeding arises, whichever is earlier, without judicial extension of time, or said claim action or proceeding is barred, time being of the essence of this paragraph. Buyer expressly waives any statutory and/or common law limitation period to the contrary.

WAIVER OF SUBROGATION: In case of any claim or loss, Buyer agrees that it is responsible to maintain, and has sufficient insurance coverage to cover, any potential claim or loss. Buyer further agrees to look to its property and/or general liability insurance carrier for reimbursement. Buyer and Seller mutually agree to release one another from any and all claims with respect to any loss covered by (or which should have been covered) the insurance coverages, which were required and/or recommended that may be applicable to any property where Seller performs Services for Buyer. For purposes of this Section, all deductibles shall be considered insured losses. The parties further mutually agree that their respective insurance companies shall have no right of subrogation against the other on account thereof.

LIMITATION OF LIABILITY: SELLER'S TOTAL LIABILITY TO BUYER FOR ANY CLAIMS, LOSSES OR DAMAGES ARISING OUT OF OR IN ANY WAY RELATED TO ANY CAUSE WHATSOEVER IN RELATION TO SERVICES PROVIDED UNDER THIS AGREEMENT, WHETHER BASED IN CONTRACT, TORT (INCLUDING NEGLIGENCE), STRICT LIABILITY, BREACH OF WARRANTY OR OTHER CAUSE, SHALL BE LIMITED TO THE RETURN OF THE PURCHASE PRICE. NOTWITHSTANDING THE FOREGOING SENTENCES, UNDER NO CIRCUMSTANCES SHALL SELLER BE LIABLE FOR ANY DAMAGES FOR LOSS OF USE, INTERRUPTION OF BUSINESS, LOST PROFITS, REVENUE OR OPPORTUNITY, CLAIMS OF THIRD PARTIES OR FOR INJURY TO PERSONS OR PROPERTY OR FOR ANY OTHER SPECIAL, EXEMPLARY, INCIDENTAL, INDIRECT, PUNITIVE, CONSEQUENTIAL OR OTHER DAMAGES OF ANY KIND OR NATURE.

INDEMNIFICATION: Buyer shall indemnify and hold harmless Seller from and against all claims, damages, losses and expenses (including attorneys' fees) arising out of the Services provided by Seller provided that any such claim, damage, loss of expense is attributable to bodily injury, sickness, disease or death or to injury to or destruction of tangible property including the loss of use resulting therefrom, and is caused in whole or in part by any act or omission of Buyer or anyone directly or indirectly employed by or serving Buyer regardless of whether or not it is caused in part by Seller. This indemnity includes claims brought by any third party, including, without limitation, Buyer's insurance company, whether the claim arises under this Agreement, warranty, tort, or any other theory of liability.

GOVERNING LAW: This Agreement is to be governed by, construed, and enforced with the laws of the State of Illinois. Buyer and Seller agree that any action brought by any party shall be brought and resolved exclusively by the state and federal courts located in Peoria County, Illinois.

SEVERABILITY: If any provision of this Agreement is held illegal or unenforceable in a judicial proceeding, such provision shall be severed and shall be inoperative, and the remainder of this Agreement shall remain operative and binding on all parties.

CLAUSE PARAMOUNT: In the event of any conflict between the terms of this Agreement and the terms of a schedule, confirmation or other documents purporting to establish the terms and conditions of the provision of Services, the terms of the schedule, confirmation or other documents shall prevail. BUYER'S ACCEPTANCE OF THIS AGREEMENT IS EXPRESSLY LIMITED TO THE TERMS OF THIS AGREEMENT.

ENTIRE AGREEMENT: This Agreement constitutes the entire agreement between the parties and no modification shall be effective unless agreed upon by both parties in writing. This Agreement supersedes all prior agreements between the parties with respect to its subject matter and constitutes (along with the documents referred to in this Agreement) a complete and exclusive statement of the terms of the agreement between the parties with respect to its subject matter.

REPRESENTATIONS: Buyer and Seller agree that no representations have been made or relied upon, except as specifically stated in this Agreement.

Report to:
Property: WCC, Weigel, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL **Zip:** 60554

Date: 10/16/2021
Job Number:
Technician:

Annual FIRE SPRINKLER INSPECTION REPORT

Central Station	POS/Acct	Handled by customer	Out	IN
-----------------	----------	---------------------	-----	----

GENERAL	YES	NO	N/A	Note #
Is the building currently occupied?	☒	☐	☐	
Has the occupancy classification and hazard of contents remained the same since the last inspection?	☒	☐	☐	
Are all fire protection systems in service?	☒	☐	☐	
Has the system remained in service without modifications or actuations of devices/alarms since last inspection?	☒	☐	☐	
Fire pump onsite?	☒	☐	☐	

SPRINKLERS (visible)	YES	NO	N/A	Note #
Free of damage or leaks?	☒	☐	☐	
Free of corrosion, foreign material, or paint, loading?	☒	☐	☐	
Installed in proper orientation?	☒	☐	☐	
Fluid in glass bulbs?	☒	☐	☐	
Spare head box contains proper number and type of heads, including wrench(s)?	☒	☐	☐	
Escutcheon plates are present and installed correctly?	☒	☐	☐	
Minimum clearance between sprinklers and storage?	☒	☐	☐	
Sprinklers tested or replaced per appropriate testing schedule?	☒	☐	☐	

Sprinkler heads in use and earliest date on heads:

Standard: ☒ 1994 Quick Response: _____ ESFR: _____ Dry Pendant: _____

PIPING	YES	NO	N/A	Note #
In good condition with no external corrosion?	☒	☐	☐	
No leaks or mechanical damage?	☒	☐	☐	
Correct alignment/No external loads?	☒	☐	☐	
Wet Sprinkler piping not exposed to freezing temperatures?	☒	☐	☐	
Hangers/bracing not damaged or loose?	☒	☐	☐	

FIRE DEPARTMENT CONNECTIONS	YES	NO	N/A	Note #
Visible and accessible?	☒	☐	☐	
Couplings swivel and operate properly?	☒	☐	☐	
Plugs or caps in place?	☒	☐	☐	
Identification signs are in place?	☒	☐	☐	
Ball drip valve is functional/not leaking?	☒	☐	☐	

ANTI-FREEZE SYSTEMS	YES	NO	N/A	Note #
Have all anti-freeze systems been tested?	☐	☐	☒	
Proper signage and placard info in place?	☐	☐	☒	

LOCATION / AREA PROTECTED	TEMP	Note #	LOCATION / AREA PROTECTED	TEMP	Note #
1			3		
2			4		

(*Any additional anti-freeze system results will be listed in Note # Section)

Report to:
Property: WCC, Weigel, 4 IL-47
Address: 4 Illinois 47
City: Sugar Grove
State: IL **Zip:** 60554

Date: 10/16/2021
Job Number:
Technician:

Annual FIRE SPRINKLER INSPECTION REPORT

<i>FIVE YEAR REQUIREMENTS</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
Have all Check Valves, Pre-action or Deluge Valves been internally inspected within the last 5 years?	☒	☐	☐	2019
Has the piping in all systems been checked for obstructive materials within the last 5 years?	☒	☐	☐	2019
System Gauges tested or replaced within the last 5 years?	☒	☐	☐	2018

<i>CONTROL VALVES</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
All Control Valves in the correct (open or closed) position?	☒	☐	☐	
Locked or supervised?	☒	☐	☐	
Easily accessible?	☒	☐	☐	
Free from damage or leaks?	☒	☐	☐	
Proper signage in place?	☒	☐	☐	
Tamper Switches operate properly?	☒	☐	☐	
All Control Valves operated through full range and return to normal position?	☒	☐	☐	
OS&Y Valves properly lubricated?	☒	☐	☐	

<i>Description</i>	<i>Type</i>	<i>Size</i>	<i>Location</i>	<i>Note #</i>
System before backflow	OS&Y	2 1/2"	Riser room - NE corner	
System after backflow	OS&Y	2 1/2"	Riser room - NE corner	

(*Any additional control valves will be listed on a separate sheet.)

<i>MAIN DRAIN AND WATERFLOW TEST RESULTS</i>	<i>YES</i>	<i>NO</i>	<i>N/A</i>	<i>Note #</i>
Do main drain test results differ more than 10% from previous test?	☐	☒	☐	

<i>System #</i>	<i>Riser Size</i>	<i>Size of Test Pipe</i>	<i>PSI Static Pressure Before</i>	<i>PSI Residual Pressure</i>	<i>PSI Pressure After</i>	<i>Waterflow Time (sec)</i>	<i>Note #</i>
Riser	2 1/2"	1 1/4"	110	65	85	W/60	

(*Any additional main drain/waterflow results will be listed on a separate sheet.)

SCOPE OF WORK

Summary

Bidder to provide contractual services for Life Safety tasks to be performed by a licensed Life Safety Contractor for all campus locations. The contract will be for three (3) years with optional two (2) one-year renewals.

The proposed agreement will include all necessary labor, equipment, supplies and materials to perform regularly scheduled maintenance of the fire and life safety systems located at all four campus locations. These tasks include:

- Annual Fire Extinguisher Certification / tagging.
- Annual Fire Extinguisher Training Class
- Annual Fire Pump Certification
- Annual Fire Sprinkler System Test/Inspect
- Semi-Annual Information Technology Fire Suppression System Test/Inspect
- Annual Fire Hydrant Test/Inspect
- Backflow Preventer Test/Inspect
- Emergency Lighting Test/Inspect
- Battery backup inverter testing

We have provided estimated quantities; however, it is the contractors responsibility to establish their own counts.

General

Contractor will establish an operational log sheet for each device which will provide a date and name associated with each service visit and maintenance inspection. This log will be affixed to the device being tested.

Contractor will be responsible to schedule and manage each service visit in advance with the Chief Plant Operator (Ed Plante) on a pre-determined schedule.

Contractor will check in at Campus Operations (Sugar Grove Campus), Campus Police service desk (DWN Aurora), and with Building Services Supervisor at the Fox Valley and Plano Campuses before any inspection begins at that campus. The contractor will notify the college campus that they are here to perform scheduled maintenance or testing. At that time, they will be required to sign in and will be provided with a Contractor Badge.

Contractor will coordinate alarm call out as needed for each location as required.

INVITATION FOR BID (IFB)
08-22-001 Life Safety Services Bid
August 19, 2022 at 10:00 a.m.

Task:	Location:	Campus:
Annual Fire Extinguisher Certification	All Locations	All Campuses (4)
Annual Fire Extinguisher training	All Locations	All Campuses (4)
Annual Science Building Fire Pump	Sugar Grove	Sugar Grove
Annual Dickson Building Fire Pump	Sugar Grove	Sugar Grove
Annual DTWN Campus Fire Pump	DTWN Aurora	DTWN Aurora
Annual Plano Campus Fire Pump	Plano	Plano
Annual and Quarterly Sprinkler test-inspect	Sugar Grove	Sugar Grove
Annual and Quarterly Sprinkler test-inspect	DTWN Aurora	DTWN Aurora
Annual and Quarterly Sprinkler test-inspect	Fox Valley	Fox Valley
Annual and Quarterly Sprinkler test-inspect	Plano	Plano
Dickson Building IT Fire Suppression semi-annual	Sugar Grove	Sugar Grove
DTWN Aurora IT Fire Suppression semi-annual	DTWN Aurora	DTWN Aurora
Plano Campus IT Fire Suppression semi-annual	Plano	Plano
Annual Dry Valve Test-Inspect	Sugar Grove	Sugar Grove
Annual Dry Valve Test-Inspect	DTWN Aurora	DTWN Aurora
Annual Dry Valve Test-Inspect	Fox Valley	Fox Valley
Annual Dry Valve Test-Inspect	Plano	Plano
Hydrant test annual	Sugar Grove	Sugar Grove
Hydrant test annual	DTWN Aurora	DTWN Aurora
Hydrant test annual	Fox Valley	Fox Valley
Hydrant test annual	Plano	Plano
Backflow Preventer test and inspect	Sugar Grove	Sugar Grove
Backflow Preventer test and Inspect	DTWN Aurora	DTWN Aurora
Backflow Preventer test and Inspect	Fox Valley	Fox Valley
Backflow Preventer test and Inspect	Plano	Plano
Emergency Lighting test and inspect	Sugar Grove	Sugar Grove
Emergency Lighting test and inspect	DTWN Aurora	DTWN Aurora
Emergency Lighting test and inspect	Fox Valley	Fox Valley
Emergency Lighting test and inspect	Plano	Plano
Emergency Light Inverter Battery test and inspect	Sugar Grove	Sugar Grove
Emergency Lights Battery and Bulbs	Sugar Grove	Sugar Grove
Emergency Lights Battery and Bulbs	Fox Valley	Fox Valley
<i>(College prefers replacement with LED Bulbs when possible)</i>		

TASK GROUPS COST WORKSHEET

Note: Hourly Labor on Repairs is for Unit Cost of one (1) hour during normal business hours

Task Groups	Campus	Approx #		Unit Cost Each	Extended
Annual Fire Extinguisher Certification	Sugar Grove	215	ea	\$ 2.50	\$ 537.50
	Aurora Downtown	74	ea	\$ 2.50	\$ 185.00
	Aurora Fox Valley	27	ea	\$ 2.50	\$ 67.50
	Plano	27	ea	\$ 2.50	\$ 67.50
	Hourly Labor on Repairs	1	ea	\$ NA	
Annual Fire Extinguisher Training Class	All four campuses – one per campus - (x4)	4	ea	\$ 525.00	\$ 2,100.00
Annual Fire Pump - Test/inspect	Sugar Grove	2	ea	\$ 1,000.00	\$ 2,000.00
	Aurora Downtown	1	ea	\$ 1,000.00	\$ 1,000.00
	Plano	1	ea	\$ 1,000.00	\$ 1,000.00
	Hourly Labor on Repairs	1	ea	\$ 500.00	
Annual Sprinkler Test-Inspect	Sugar Grove	22	ea	\$ 500.00	\$ 11,000.00
	Aurora Downtown	2	ea	\$ 500.00	\$ 1,000.00
	Aurora Fox Valley	2	ea	\$ 500.00	\$ 1,000.00
	Plano	2	ea	\$ 500.00	\$ 1,000.00
	Hourly Labor on Repairs	1	ea	\$ 500.00	
Hydrant Test Annual	Sugar Grove	17 Buildings	ea	\$ 200.00	\$ 3,400.00
	Aurora Downtown	1 Building	ea	\$ 200.00	\$ 200.00
	Aurora Fox Valley	1 Building	ea	\$ 200.00	\$ 200.00
	Plano	1 Building	ea	\$ 200.00	\$ 200.00
	Hourly Labor on Repairs	1	ea	\$ 200.00	
Semi-Annual IT Fire Suppression System Test-Inspect	Sugar Grove	1	ea	\$ 1,400.00	\$ 1,400.00
	Aurora Downtown	1	ea	\$ 1,200.00	\$ 1,200.00
	Plano	1	ea	\$ 1,200.00	\$ 1,200.00
	Hourly Labor on Repairs	1	ea	\$ 500.00	

INVITATION FOR BID (IFB)
08-22-001 Life Safety Services Bid
August 19, 2022 at 10:00 a.m.

Task	Campus	Approx #		Unit Cost Each	Extended
Annual Dry Valve Test-Inspect	Sugar Grove	2	ea	\$ 200.00	\$ 400.00
	Aurora Downtown	1	ea	\$ 200.00	\$ 200.00
	Aurora Fox Valley	1	ea	\$ 200.00	\$ 200.00
	Plano	1	ea	\$ 200.00	\$ 200.00
	Hourly Labor on Repairs	1	ea	\$ 200.00	
Buckflow Valve Test-Inspect	Sugar Grove	7	ea	\$ 200.00	\$ 1,400.00
	Aurora Downtown	1	ea	\$ 200.00	\$ 200.00
	Aurora Fox Valley	1	ea	\$ 200.00	\$ 200.00
	Plano	1	ea	\$ 200.00	\$ 200.00
	Hourly Labor on Repairs	1	ea	\$ 200.00	
Emergency & Exit Lighting Test-Inspect	Sugar Grove	569	ea	\$ 10.00	\$ 5,690.00
	Aurora Downtown	83	ea	\$ 10.00	\$ 830.00
	Aurora Fox Valley	87	ea	\$ 10.00	\$ 870.00
	Plano		ea	\$ 10.00	\$ 10.00
	Hourly Labor on Repairs	1	ea	\$ 10.00	
Emergency & Exit Light Parts and Labor (Unit pricing only. Do not add to Base Bid.)	6v/4-amp Battery	1	ea	\$ 22.80	
	6v/4.5-amp Battery	1	ea	\$ 22.80	
	6v/8-amp Battery	1	ea	\$ 11.75	
	6v/10-amp Battery	1	ea	\$ N/A	
	6v/12-amp Battery	1	ea	\$ 49.00	
	Incandescent Blub	1	ea	\$ N/A	
	LED Bulb	1	ea	\$ 5.00	
	Fluorescent Bulb	1	ea	\$ 6.00	
Battery Inverter Emergency Lighting Test-Inspect	Sugar Grove Field House	7	ea	\$ 29.50	\$ 206.50
	Replacement Battery	84	ea	\$ 29.50	
	Replacement Capacitor	7	ea	\$ N/A	
	Hourly Labor on Repairs	1	ea	\$ N/A	
Total Base Bid All Task Groups – Extended Pricing Only					\$53,364.00

1. The first part of the document is a list of the names of the persons who have been appointed to the various positions of the Board of Directors of the Corporation.

2. The second part of the document is a list of the names of the persons who have been appointed to the various positions of the Board of Directors of the Corporation.

3. The third part of the document is a list of the names of the persons who have been appointed to the various positions of the Board of Directors of the Corporation.

4. The fourth part of the document is a list of the names of the persons who have been appointed to the various positions of the Board of Directors of the Corporation.

5. The fifth part of the document is a list of the names of the persons who have been appointed to the various positions of the Board of Directors of the Corporation.