

ADDENDUM 2 – April 9, 2018

PROJECT: 03-18-003 – Pavement Improvements, Repairs and Maintenance Bid - Addendum 2
BID / TIME DUE: April 11, 2018 @ 2:00 p.m.

Bidder must acknowledge receipt of this addendum on Bid Form.

QUESTION

1. Will it be required to mow the new seeded area's once the new grass comes in?
 - a. No mowing is required. Please DELETE note number 7 on page CS100.
2. Sheet CS100 has a proposed grade of 703 in the new landscape area on the South side of the Well House building. I want to confirm that this is correct or is it suppose to be 704?
 - a. Yes, this was an oversight; the contour line should be labeled with 704 to match the existing grade line. This will be corrected on "issued for construction" drawings.
3. Does the Plano location have any work in the base bid or is it only an alternate?
 - a. The Plano campus is only included in the bid alternates.

This addendum does not change the bid due date or time.

END OF DOCUMENT

Sugar Grove

Rt. 47 at Waubonsee Drive
Sugar Grove, IL 60554-9454
(630) 466-7900

Aurora Downtown

18 S. River St.
Aurora, IL 60506-4131
(630) 801-7900

Aurora Fox Valley

2060 Ogden Ave.
Aurora, IL 60504-7222
(630) 585-7900

Plano

100 Waubonsee Drive
Plano, IL 60545-2276
(630) 552-7900