

ADDENDUM 1

PROJECT: 01-19-003 Baseball Field Renovation Bid - Addendum 1
REVISED BID / TIME DUE: February 13, 2019 @ 1:00 p.m.

Bidder must acknowledge receipt of this addendum on Bid Form.

Changes:

1. Add Alternate #2 - Provide pricing to re-use existing field mix for the infield vs replacing with Sure-HOP red infield mix.
2. Use revised Bid Form included with this addendum.

Clarifications:

1. New infield includes adding field mix basepaths from home to 1st and 3rd base per NCAA specs.
2. On deck circles and a walking path from the dug-outs to on-deck circles to the home plate circle should also be field mix.
3. Maintain the proposed schedule per the bid specification with work starting as soon as the baseball team's spring season has finished (anticipated mid-late May, depending on how deep of a playoff run the team makes).
 - a. It should still be listed as a bid alternate, but we are anticipating going ahead with sodding all turf areas.
4. Yes, we do want a conditioner used with the field mix.
5. No work on the bullpens or batting cages is included for the project.
6. Existing field mix is to be re-located on the Sugar Grove campus. Planned location is east of the softball field.
7. Any spoils generated from removal of existing turf can be dumped on the Sugar Grove campus. Possible locations will be near the OPS building or in the composter/dump in the forested area south of the south entrance to the campus.
8. The water access for the quick coupler is an existing hydrant off the northwest corner of the field.
9. While we don't know the exact elevation, it is assumed the infield will be raised to achieve a 1% pitch and proper drainage. To maintain the 1% pitch and drainage, it is possible the grading will need to be altered beyond the base-paths, behind home plate and beyond the infield radius. Contractor is expected to "feather" the grading to maintain drainage. Any turf areas that require grading alterations are to be seeded (or assumed into the alternate pricing for sod).
10. Sure-Hop infield mix should be approximately 2" deep.

This addendum changes the bid due date or time.

END OF DOCUMENT

BID FORM - REVISED BY ADDENDUM 1

All Bidders are required to complete and sign this form. Please print clearly. Attach a detailed proposal with a breakdown of costs for all equipment, delivery, installation and training.

Total Base Bid

Having examined the bid documents, as prepared by Waubensee Community College, and having inspected the site and the conditions affecting and governing the construction of said Project, the Bidder hereby proposes to furnish all labor and materials, supervision, coordination, transportation, services and equipment for the sum of:

TOTAL BID \$ _____ **Total**
In Figures

In Words

ALTERNATE #1 – INSTALL SOD INSTEAD OF SEED AND STRAW FOR INFIELD AND OUTFIELD

ADD / DEDUCT \$ _____ **Total**
In Figures

In Words

ALTERNATE #2 – REUSE EXISTING FIELD MIX FOR THE INFIELD VS REPLACING WITH SURE-HOP RED INFIELD MIX.

ADD / DEDUCT \$ _____ **Total**
In Figures

In Words

Acknowledgement of Addenda

I acknowledge having received addenda # _____.